

B&A Plumbing, Inc

619 Estes Avenue. Schaumburg, IL 60193

Phone: 847-985-2444 Fax: 847-985-7677

2021 YR.



Cross Connection Control Device Testing & Certification Report

Manufacturer: Wilkins Model: 975XL Size: 3/4" Serial #: 2550995

Name of Owner: Waveland-Wheaton Property Partners Phone: _____

Address (Street, City, Zip): 120 E. Liberty Street Wheaton, IL 60187

Location of Device In Building: Mechanical Room

Piping System: Fire By-Pass RPZ: X DBC: _____ DBDC: _____

Check Valve # 1

Initial Leaked ☐
Test Closed Tight ☐

Differential 8.0 DPSI
Pressure

Final Test Closed Tight ☒

Alarm #: _____

Check Valve # 2

Leaked ☐
Closed Tight ☐

7.8 DPSI

Closed Tight ☒

Operator #: _____

Relief Valve

Opened @ _____ PSI ☐
Reduced Pressure ☐
Did Not Open

Opened @ 3.0 PSI ☒
Reduced Pressure

Description of Repairs:

Special Comments:

Final Test By:

James Hermann - Plumbing Lic# 058-190695 CCCDI# XC4255 - ☐

Donald Medlin - Plumbing Lic# 058-157447 CCCDI# XC2951 - ☒

Date: Jan 11-21 Time: 9:36

This report is certified to be true: (Name): [Signature]

PASS - ☒

FAIL - ☐

2021 YR.

B&A Plumbing, Inc

619 Estes Avenue. Schaumburg, IL 60193

Phone: 847-985-2444 Fax: 847-985-7677



Cross Connection Control Device Testing & Certification Report

Manufacturer: Watts Model: 009 Size: 3" Serial #: 28511

Name of Owner: Waveland-Wheaton Property Partners Phone: _____

Address (Street, City, Zip): 120 E. Liberty Street Wheaton, IL 60187

Location of Device In Building: Mechanical Room

Piping System: Domestic RPZ: X DBC: _____ DBDC: _____

Check Valve # 1		Check Valve # 2		Relief Valve	
Initial	Leaked	Leaked		Opened @ _____	PSI
Test	Closed Tight	Closed Tight		Reduced Pressure	
				Did Not Open	
Differential	<u>9.2</u>	DPSI	<u>7.8</u>	DPSI	
Pressure					
Final Test	Closed Tight	Closed Tight		Opened @ <u>30</u>	PSI
				Reduced Pressure	
Alarm #:	_____	Operator #:	_____		

Description of Repairs:

Special Comments:

Final Test By:

James Hermann - Plumbing Lic# 058-190695 CCCDI# XC4255 - ☐

Donald Medlin - Plumbing Lic# 058-157447 CCCDI# XC2951 - ☒

Date: Jan 11.21 Time: 9:12

This report is certified to be true: (Name): [Signature]

PASS - ☒

FAIL - ☐

B&A Plumbing, Inc
619 Estes Avenue. Schaumburg, IL 60193
Phone: 847-985-2444 Fax: 847-985-7677

2021 YR.



Cross Connection Control Device Testing & Certification Report

Manufacturer: Wilkins Model: 375 Size: 6" Serial #: Y02257

Name of Owner: Waveland-Wheaton Property Partners Phone: _____

Address (Street, City, Zip): 120 E. Liberty Street Wheaton, IL 60187

Location of Device In Building: Mechanical Room

Piping System: Fire RPZ: X DBC: _____ DBDC: _____

	Check Valve # 1		Check Valve # 2		Relief Valve
Initial	Leaked	<input type="checkbox"/>	Leaked	<input type="checkbox"/>	Opened @ _____ PSI <input type="checkbox"/>
Test	Closed Tight	<input type="checkbox"/>	Closed Tight	<input type="checkbox"/>	Reduced Pressure
					Did Not Open
Differential	<u>8.4</u>	DPSI	<u>8.0</u>	DPSI	
Pressure					
Final Test	Closed Tight	<input checked="" type="checkbox"/>	Closed Tight	<input checked="" type="checkbox"/>	Opened @ <u>30</u> PSI <input checked="" type="checkbox"/>
					Reduced Pressure
Alarm #:	_____		Operator #:	_____	

Description of Repairs:

Special Comments:

Final Test By:

James Hermann - Plumbing Lic# 058-190695 CCCDI# XC4255 - ☐

Donald Medlin - Plumbing Lic# 058-157447 CCCDI# XC2951 - ☒

Date: Jan 11-21 Time: 9:29

This report is certified to be true: (Name): [Signature]

PASS - ☒

FAIL - ☐