

B&A Plumbing, Inc
619 Estes Avenue. Schaumburg, IL 60193
Phone: 847-985-2444 Fax: 847-985-7677



Cross Connection Control Device Testing & Certification Report

Manufacturer: Wilkins Model: 975XL Size: 3/4" Serial #: 2550995

Name of Owner: Waveland-Wheaton Property Partners Phone: _____

Address (Street, City, Zip): 120 E. Liberty Street Wheaton, IL 60187

Location of Device In Building: Mechanical Room

Piping System: Fire By-Pass RPZ: X DBC: _____ DBDC _____

	Check Valve # 1	Check Valve # 2	Relief Valve
Initial Test	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Opened @ _____ PSI <input type="checkbox"/> Reduced Pressure <input type="checkbox"/> Did Not Open <input type="checkbox"/>
Differential Pressure	<u>7.6</u> DPSI	<u>7.2</u> DPSI	
Final Test	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened @ <u>3.4</u> PSI <input checked="" type="checkbox"/> Reduced Pressure <input type="checkbox"/>
Alarm #:	_____	Operator #:	_____

Description of Repairs:

Special Comments:

Final Test By:

- James Hermann - Plumbing Lic# 058-190695 CCCDI# XC4255
- Michael J. Freier - Plumbing Lic# 058-175837 CCCDI# XC4045 -
- Donald Medlin - Plumbing Lic# 058157447 CCCDI# XC2951 -

Date: 1-9-20 Time: 7:55

This report is certified to be true: (Name): [Signature]

PASS -

FAIL -

B&A Plumbing, Inc
619 Estes Avenue. Schaumburg, IL 60193
Phone: 847-985-2444 Fax: 847-985-7677



Cross Connection Control Device Testing & Certification Report

Manufacturer: Wilkins Model: 375 Size: 6" Serial #: Y02257

Name of Owner: Waveland-Wheaton Property Partners Phone: _____

Address (Street, City, Zip): 120 E. Liberty Street Wheaton, IL 60187

Location of Device In Building: Mechanical Room

Piping System: Fire RPZ: X DBC: _____ DBDC _____

	Check Valve # 1	Check Valve # 2	Relief Valve
Initial Test	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Opened @ _____ PSI <input type="checkbox"/> Reduced Pressure <input type="checkbox"/> Did Not Open <input type="checkbox"/>
Differential Pressure	<u>8.4</u> DPSI	<u>8.0</u> DPSI	
Final Test	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened @ <u>2.5</u> PSI <input checked="" type="checkbox"/> Reduced Pressure <input checked="" type="checkbox"/>
Alarm #:	_____	Operator #:	_____

Description of Repairs:

Special Comments:

Final Test By:

James Hermann - Plumbing Lic# 058-190695 CCCDI# XC4255 -

Michael J. Freier - Plumbing Lic# 058-175837 CCCDI# XC4045 -

Donald Medlin - Plumbing Lic# 058157447 CCCDI# XC2951 -

Date: 1-9-20 Time: 7:50

This report is certified to be true: (Name): [Signature]

PASS - FAIL -

B&A Plumbing, Inc
619 Estes Avenue. Schaumburg, IL 60193
Phone: 847-985-2444 Fax: 847-985-7677



Cross Connection Control Device Testing & Certification Report

Manufacturer: Watts Model: 009 Size: 3" Serial #: 28511
Name of Owner: Waveland-Wheaton Property Partners Phone: _____
Address: (Street, City, Zip): 120 E. Liberty Street Wheaton, IL 60187
Location of Device In Building: Mechanical Room
Piping System: Domestic RPZ: X DBC: _____ DBDC _____

	Check Valve # 1	Check Valve # 2	Relief Valve
Initial Test	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/>	Opened @ _____ PSI <input type="checkbox"/> Reduced Pressure <input type="checkbox"/> Did Not Open <input type="checkbox"/>
Differential Pressure	<u>8.8</u> DPSI	<u>8.4</u> DPSI	
Final Test	Closed Tight <input checked="" type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/>	Opened @ <u>2.5</u> PSI <input checked="" type="checkbox"/> Reduced Pressure <input type="checkbox"/>
Alarm #:	_____	Operator #:	_____

Description of Repairs:

Special Comments:

Final Test By:

James Hermann - Plumbing Lic# 058-190695 CCCDI# XC4255 -
Michael J. Freier - Plumbing Lic# 058-175837 CCCDI# XC4045 -
Donald Medlin - Plumbing Lic# 058157447 CCCDI# XC2951 -

Date: 1-9-20 Time: 8:10

This report is certified to be true: (Name): 

PASS -

FAIL -