




**PERIODIC TESTS OF HYDRAULIC ELEVATORS**

**H 54355**

 <b>EISW / Elevator Inspection Service - W</b>	Date <u>12 / 27 / 2022</u>
	V - T - C <u>Sandwich</u>
	State of IL Reg. I.D. # <u>H016778</u>
	P.O.#
Bldg. Name: <u>Valley West Med Ctr</u>	Bldg. I.D. <u>Pass</u>
Address: <u>1310 N Main</u>	Passy / Freight / Service - Make: <u>OTIS</u>
Bldg. Phone:	Speed: <u>100</u> Capacity: <u>4500</u>
Owner / Manager / Elev. Co.	



Category 1 Test Requirement 8.6.5.14	ASME Section	Pass	Fail	N/A
Relief Valve Setting & System Pressure Test	8.6.5.14.1	✓		
Hydraulic Cylinders & Pressure Piping	8.6.5.14.2	✓		
Normal Terminal Stopping Devices	8.6.4.19.5	✓		
Governors, Overspeed Switch and Seals	8.6.4.19.3			✓
Safeties	8.6.4.19.2			✓
Oil Buffers	8.6.4.19.1			✓
Firefighter's Emergency Operation	8.6.4.19.6	✓		
Standby Power Operation	8.6.4.19.7			✓
Power Operation of Door System	8.6.4.19.8	✓		
Emergency Terminal Speed Reducing Devices	3.25.2			✓
Low Oil Protection Devices	3.26.9	✓		
Flexible Hose & Fitting Assemblies	8.6.5.14.4			✓
Pressure Switch	8.6.5.14.5	✓		

Category 3 Test Requirement 8.6.5.15	ASME Section	Pass	Fail	N/A
Unexposed Portions of Pistons	8.6.5.15.1			
Pressure Vessels	8.6.5.15.2			

Category 5 Test Requirement 8.6.5.16	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1			
Governors	8.6.4.20.2			
Oil Buffers	8.6.4.20.3			
Coated Ropes	8.6.5.16.2			
Wire Rope Fastenings	8.6.5.16.3			
Plunger Gripper	8.6.5.16.4			
Overspeed Valves	8.6.5.16.5			

Witness Pressure Test			
Empty Working Pressure	<u>240</u> psi	Full Load Pressure	<u>600</u> psi
Relief Valve Setting was	<u>660</u> psi	Relief Valve Setting is	<u>680</u> psi
Pressure Held 15 min	Yes <input type="checkbox"/> No <input type="checkbox"/>		

Comments:

 Signature of Inspector <span style="float: right;">QEI #</span>	 Signature of Person Conducting Test & State License #
<u>06017</u>	<u>OTIS 03083</u>
Inspector's State of Illinois License #	Employed by (Company Name)