

FIRE EXTINGUISHER

Customer Information

Name Landmark Michigan

Building Information

Name Troy Campus Medical Building, LLC

Address 44344 Dequindre Road, Sterling Heights, MI 48314

Inspection Information

Name Fire Extinguisher

SR# 53385034

Frequency Annual

Timezone GMT-04:00

Account Information

Name Johnson Controls North America

Address 24755 Halsted Rd. Farmington Hills, MI. 48335

Phone 248-427-5050

Office License _____

Date 11/04/2022

Inspector License _____

Contact Information

Name Dan Przyski

Role Maintenance

E-Mail dprzyski@continuumservices.com

Phone 12489962489

| INSPECTION RESULTS SUMMARY | | | | |
|----------------------------|-----------------|-----------|----------|----------------|
| DEVICE TYPE | INVENTORY COUNT | PASSED | FAILED | CANNOT INSPECT |
| ABC Extinguisher | 34 | 33 | 1 | 0 |
| Extinguisher - CO2 | 1 | 1 | 0 | 0 |
| TOTAL | 35 | 34 | 1 | 0 |

COMING 5 YEAR MAINTENANCE DUE

| DEVICE TYPE | TOTAL | IN THE NEXT 3 YEARS | NEXT YEAR | DUE THIS YEAR |
|--------------------|-------|---------------------|-----------|---------------|
| Extinguisher - CO2 | 1 | 0 | 0 | 0 |

COMING 6 YEAR MAINTENANCE DUE

| DEVICE TYPE | TOTAL | IN THE NEXT 3 YEARS | NEXT YEAR | DUE THIS YEAR |
|------------------|-------|---------------------|-----------|---------------|
| ABC Extinguisher | 34 | 2 | 0 | 15 |

6 YEAR MAINTENANCE DUE THIS YEAR

ABC EXTINGUISHER

| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
|---|-------------------------|----------------------|--------------|----------------------|-----------------|--------------|---------------------|
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | LAST 6yr MAINTENANCE | LAST 12yr HYDRO | | |
| 1 | — | 1st floor | — | ZX-260184 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 2 | — | 1st floor eye clinic | — | jr920188 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 06/23/2009 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 3 | — | 1st floor hall | — | ZU310780 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 4 | — | 1st floor pharmacy | — | — | Ryan Fair | 11/04/2022 | Failed |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2008 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| 5 | — | 2nd floor hall | — | WA-615115 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 04/23/2016 | — | | |
| 6 | — | 2nd floor hall | — | XV-71398 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 7 | — | 3rd floor hall | — | ZN828025 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| 8 | — | 4th floor hall | — | ZU306236 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 9 | — | 4th floor hall | — | ZX-260195 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 10 | — | 5th floor hall | — | ZU307766 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 11 | — | 5th floor hall | — | MV-561440 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 12 | — | Elevator mech room | — | XA10H | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |

| ABC EXTINGUISHER | | | | | | | |
|---|-------------------------|-------------|--------------|----------------------|-----------------|--------------|---------------------|
| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | LAST 6yr MAINTENANCE | LAST 12yr HYDRO | | |
| 13 | — | Suite 260 | — | MN-070756 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 06/23/2006 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 14 | — | Suite 360 | — | WG517890 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 11/23/2012 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 15 | — | Suite 450 | — | — | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 06/23/2009 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |

6 YEAR MAINTENANCE DUE IN 3 YEARS

| ABC EXTINGUISHER | | | | | | | |
|------------------|-------------------------|-------------|--------------|----------------------|-----------------|--------------|--------|
| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | LAST 6yr MAINTENANCE | LAST 12yr HYDRO | | |
| 1 | — | Suite 320 | — | WS501620 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 03/23/2018 | — | | |
| 2 | — | Suite 510 | — | XK-508960 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 03/23/2018 | — | | |

COMING 12 YEAR MAINTENANCE DUE

| DEVICE TYPE | TOTAL | IN THE NEXT 3 YEARS | NEXT YEAR | DUE THIS YEAR |
|------------------|-------|---------------------|-----------|---------------|
| ABC Extinguisher | 34 | 0 | 0 | 0 |

| DEVICE DEFICIENCIES | | | | | | | | | |
|----------------------------------|--------------------|---------|------------------|------|-------|---------|--------------|--------------------|--------|
| LOCATION | DESCRIPTION | ADDRESS | DEVICE | MAKE | MODEL | BARCODE | DATE OF TEST | TYPE | IMAGES |
| — | 1st floor pharmacy | — | ABC Extinguisher | — | — | — | 11/04/2022 | FUNCTIONAL FAILURE | — |
| FAILURE REASON: Needs hydro test | | | | | | | | | |

| REPAIRED DEVICES | | | | | | | | | |
|--|-------------|---------|------------------|------|-------|-----------|--------------|---------------------|--|
| LOCATION | DESCRIPTION | ADDRESS | DEVICE | MAKE | MODEL | BARCODE | DATE OF TEST | TYPE | |
| — | 1st floor | — | ABC Extinguisher | — | — | ZX-260184 | 11/04/2022 | PASSED AFTER REPAIR | |
| INITIAL FAILURE REASON: Needs hydro test | | | | | | | | | |
| RESOLUTION: Replaced tank | | | | | | | | | |

| REPAIRED DEVICES | | | | | | | | |
|---|----------------------|---------|------------------|------|-------|-----------|--------------|---------------------|
| LOCATION | DESCRIPTION | ADDRESS | DEVICE | MAKE | MODEL | BARCODE | DATE OF TEST | TYPE |
| — | 1st floor eye clinic | — | ABC Extinguisher | — | — | jr920188 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 1st floor hall | — | ABC Extinguisher | — | — | ZU310780 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 2nd floor hall | — | ABC Extinguisher | — | — | XV-71398 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 3rd floor hall | — | ABC Extinguisher | — | — | CG599856 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 4th floor hall | — | ABC Extinguisher | — | — | ZU306236 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 4th floor hall | — | ABC Extinguisher | — | — | ZX-260195 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 5th floor hall | — | ABC Extinguisher | — | — | ZU307766 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | 5th floor hall | — | ABC Extinguisher | — | — | MV-561440 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | Elevator mech room | — | ABC Extinguisher | — | — | XA10H | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | Suite 260 | — | ABC Extinguisher | — | — | MN-070756 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | Suite 360 | — | ABC Extinguisher | — | — | WG517890 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |

| REPAIRED DEVICES | | | | | | | | |
|---|-------------|---------|------------------|------|-------|----------|--------------|---------------------|
| LOCATION | DESCRIPTION | ADDRESS | DEVICE | MAKE | MODEL | BARCODE | DATE OF TEST | TYPE |
| — | Suite 420 | — | ABC Extinguisher | — | — | T120345 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | Suite 450 | — | ABC Extinguisher | — | — | — | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | Suite 460 | — | ABC Extinguisher | — | — | BN362822 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |
| — | Suite 540 | — | ABC Extinguisher | — | — | AV445075 | 11/04/2022 | PASSED AFTER REPAIR |
| <i>INITIAL FAILURE REASON: Needs hydro test</i> | | | | | | | | |
| <i>RESOLUTION: Replaced tank</i> | | | | | | | | |

| ABC EXTINGUISHER | | | | | | | |
|---|-------------------------|----------------------|--------------|----------------------|-----------------|--------------|---------------------|
| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | LAST 6yr MAINTENANCE | LAST 12yr HYDRO | | |
| 1 | — | 1st floor | — | ZX-260184 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 2 | — | 1st floor eye clinic | — | jr920188 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 06/23/2009 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 3 | — | 1st floor hall | — | ZU310780 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 4 | — | 1st floor pharmacy | — | — | Ryan Fair | 11/04/2022 | Failed |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2008 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| 5 | — | 2nd floor hall | — | WA-615115 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 04/23/2016 | — | | |
| 6 | — | 2nd floor hall | — | XV-71398 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 7 | — | 2nd floor Suite 210 | — | — | Ryan Fair | 11/04/2022 | Passed |
| | — | — | — | — | — | | |
| 8 | — | 3rd floor hall | — | ZN828025 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| 9 | — | 3rd floor hall | — | CG599856 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2014 | — | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 10 | — | 4th floor hall | — | ZU306236 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 11 | — | 4th floor hall | — | ZX-260195 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 12 | — | 5th floor hall | — | ZU307766 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 08/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 13 | — | 5th floor hall | — | MV-561440 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2014 | — | | |

| ABC EXTINGUISHER | | | | | | | |
|--|-------------------------|--------------------|--------------|----------------------|-----------------|--------------|---------------------|
| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | LAST 6yr MAINTENANCE | LAST 12yr HYDRO | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 14 | — | Elevator mech room | — | E-83220732 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | | |
| 15 | — | Elevator mech room | — | XA10H | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 07/23/2014 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 16 | — | Suite 260 | — | E-83220724 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | | |
| 17 | — | Suite 260 | — | MN-070756 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 06/23/2006 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 18 | — | Suite 260 | — | E-83220731 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | | |
| 19 | — | Suite 310 | — | E-83220725 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | | |
| 20 | — | Suite 320 | — | WS501620 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | — | 03/23/2018 | — | | |
| 21 | — | Suite 340 | — | E-83220723 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | | |
| 22 | — | Suite 350 | — | AV445091 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2012 | — | — | | |
| 23 | — | Suite 360 | — | WG517890 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 11/23/2012 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 24 | — | Suite 420 | — | T120345 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2010 | — | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 25 | — | Suite 450 | — | — | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 10 lbs | — | 06/23/2009 | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 26 | — | Suite 460 | — | BN362822 | Ryan Fair | 11/04/2022 | Passed After Repair |
| | ABC - Stor Press Refill | 5 lbs | 01/23/2013 | — | — | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |
| 27 | — | Suite 470 | — | E-93512350 | Ryan Fair | 11/03/2022 | Passed |
| | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | | |
| 28 | — | Suite 480 | — | E-83220708 | Ryan Fair | 11/03/2022 | Passed |

ABC EXTINGUISHER

| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
|--|-------------------------|-------------|--------------|----------------------|-----------------|--------------|---------------------|
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | LAST 6yr MAINTENANCE | LAST 12yr HYDRO | | |
| 29 | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | 11/03/2022 | Passed |
| | — | Suite 490 | — | E-93512353 | Ryan Fair | | |
| 30 | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | 11/03/2022 | Passed |
| | — | Suite 510 | — | E-83220722 | Ryan Fair | | |
| 31 | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | 11/03/2022 | Passed |
| | — | Suite 510 | — | XK-508960 | Ryan Fair | | |
| 32 | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | 11/03/2022 | Passed |
| | — | Suite 510 | — | E-83220733 | Ryan Fair | | |
| 33 | ABC - Stor Press Refill | 10 lbs | 01/23/2018 | — | — | 11/03/2022 | Passed |
| | — | Suite 520 | — | E-83220719 | Ryan Fair | | |
| 34 | ABC - Stor Press Refill | 10 lbs | 01/23/2012 | — | — | 11/04/2022 | Passed After Repair |
| | — | Suite 540 | — | AV445075 | Ryan Fair | | |
| Reason for failure: (Functional Failure) Needs hydro test | | | | | | | |
| Resolution: Replaced tank | | | | | | | |

EXTINGUISHER - CO2

| # | LOCATION | DESCRIPTION | MODEL | BARCODE | INSPECTOR | DATE OF TEST | RESULT |
|---|------------|----------------------|--------------|--------------------------|----------------|--------------|--------|
| | AGENT TYPE | EXT SIZE | MFG NEW DATE | ANNUAL CONDUCTIVITY TEST | LAST 5yr HYDRO | | |
| 1 | — | 1st floor mechanical | — | B78704832 | Ryan Fair | 11/03/2022 | Passed |
| | Co2 | 10 lbs | 07/23/2016 | Pass | — | | |

| | | |
|--|--|---------------------------------|
| Inspector Signature _____ | Inspector Name _____ Ryan Fair | Date _____ 11/04/2022 |
| Signature of the RSSR _____ | Printed name of the RSSR _____ Ryan Fair | Date _____ 11/04/2022 |

Terms And Conditions

- 1. Limitation of Liability; Limitations Of Remedy.** It is understood and agreed by the Customer that Company is not an insurer and that insurance coverage, if any, shall be obtained by the Customer and that amounts payable to Company hereunder are based upon the value of the services and the scope of liability set forth in this agreement and are unrelated to the value of the Customer's property and the property of others located on the premises. Customer agrees to look exclusively to the Customer's insurer to recover for injuries or damage in the event of any loss or injury and that Customer releases and waives all right of recovery against Company arising by way of subrogation. Company makes no guaranty or Warranty, including any implied warranty of merchantability or fitness for a particular purpose that equipment or services supplied by Company will detect or avert occurrences or the consequences there from that the equipment or service was designed to detect or avert. It is impractical and extremely difficult to fix the actual damages, if any, which may proximately result from failure on the part of Company to perform any of its obligations under this agreement. Accordingly, Customer agrees that, Company shall be exempt from liability for any loss, damage or injury arising directly or indirectly from occurrences, or the consequences therefrom, which the equipment or service was designed to detect or avert. Should Company be found liable for any loss, damage or injury arising from a failure of the equipment or service in any respect, Company's liability shall be limited to an amount equal to the agreement price (as increased by the price for any additional work) or where the time and material payment term is selected, Customer's time and material payments to Company. Where this agreement covers multiple sites, liability shall be limited to the amount of the payments allocable to the site where the incident occurred. Such sum shall be complete and exclusive. If Customer desires Company to assume greater liability, the parties shall amend this agreement by attaching a rider setting forth the amount of additional liability and the additional amount payable by the Customer for the assumption by Company of such greater liability, provided however that such rider shall in no way be interpreted to hold Company as an insurer. IN NO EVENT SHALL COMPANY BE LIABLE FOR ANY DAMAGE, LOSS, INJURY, OR ANY OTHER CLAIM ARISING FROM ANY SERVICING, ALTERATIONS, MODIFICATIONS, CHANGES, OR MOVEMENTS OF THE COVERED SYSTEM(S) OR ANY OF ITS COMPONENT PARTS BY THE CUSTOMER OR ANY THIRD PARTY. COMPANY SHALL NOT BE LIABLE FOR INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OF ANY KIND, INCLUDING BUT NOT LIMITED TO DAMAGES ARISING FROM THE USE, LOSS OF THE USE, PERFORMANCE, OR FAILURE OF THE COVERED SYSTEM(S) TO PERFORM. The limitations of liability set forth in this agreement shall inure to the benefit of all parents, subsidiaries and affiliates of Company, whether direct or indirect, Company's employees, agents, officers and directors.
- 2. Limited Warranty.** COMPANY WARRANTS THAT ITS WORKMANSHIP AND MATERIAL FURNISHED UNDER THIS AGREEMENT WILL BE FREE FROM DEFECTS FOR A PERIOD OF NINETY (90) DAYS FROM THE DATE OF FURNISHING. Where Company provides product or equipment of others, Company will warrant the product or equipment only to the extent warranted by such third party. EXCEPT AS EXPRESSLY SET FORTH HEREIN, COMPANY DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE WITH RESPECT TO THE SERVICES PERFORMED OR THE PRODUCTS, SYSTEMS OR EQUIPMENT, IF ANY, SUPPORTED HEREUNDER. COMPANY MAKES NO WARRANTY OR REPRESENTATION, AND UNDERTAKES NO OBLIGATION TO ENSURE BY THE SERVICES PERFORMED UNDER THIS AGREEMENT, THAT COMPANY'S PRODUCTS OR THE SYSTEMS OR EQUIPMENT OF THE CUSTOMER WILL CORRECTLY HANDLE THE PROCESSING OF CALENDAR DATES BEFORE OR AFTER DECEMBER 31, 1999.
- 3. Indemnity.** Customer agrees to indemnify, hold harmless and defend Company against any and all losses, damages, costs, including expert fees and costs, and expenses including reasonable defense costs, arising from any and all third party claims for personal injury, death, property damage or economic loss, including specifically any damages resulting from the exposure of workers to Hazardous Conditions whether or not Customer pre-notifies Company of the existence of said hazardous conditions, arising in any way from any act or omission of Customer or Company relating in any way to this agreement, including but not limited to the Services under this agreement, whether such claims are based upon contract, warranty, tort (including but not limited to active or passive negligence), strict liability or otherwise. Company reserves the right to select counsel to represent it in any such action.
- 4. Hazardous Materials.** Customer represents that, except to the extent that Company has been given written notice of the following hazards prior to the execution of this agreement, to the best of Customer's knowledge there is no:

 - a. "permit confined space," as defined by OSHA, or space in which work must be performed that, because of its construction, location, contents or work activity therein, accumulation of a hazardous gas, vapour, dust or fume or the creation of a risk of infectious disease
 - b. need for air monitoring, respiratory protection, or other medical risk
 - c. asbestos, asbestos-containing material, formaldehyde or other potentially toxic or otherwise hazardous material contained in or on the surface of the floors, walls, ceilings, insulation or other structural components of the area of any building
 - d. All of the above are hereinafter referred to as "Hazardous Conditions". Company shall have the right to rely on the representations listed above. If hazardous conditions are encountered by Company during the course of Company's work, the discovery of such conditions shall constitute an event beyond Company's control and Company shall have no obligation to further perform in the area where the hazardous conditions exist until the area has been made safe by Customer as certified in writing by an independent testing agency, and Customer shall pay disruption expenses and re-mobilization expenses as determined by Company. This agreement does not provide for the cost of capture, containment or disposal of any hazardous waste materials, or hazardous materials, encountered in any of the Covered System(s) and/or during performance of the Services. Said materials shall at all times remain the responsibility and property of Customer. Company shall not be responsible for the testing, removal or disposal of such hazardous materials.
- 5. Equipment Disconnections.** This represents Company's notice to you that the system(s)/device(s) listed on the face of this agreement as temporarily or permanently disconnected are no longer in service and, thus, cannot detect, perform and/or report
- 6. General.** Unless otherwise specified, work shall be performed during company's regular business hours,, exclusive of Saturdays, Sundays and Company holidays. All work is subject to review and rebilling in accordance with the terms and conditions of Customer's agreement/contract with Company, if one is in effect. Company shall not be responsible for failure to render services due to causes beyond its control, including but not limited to material shortages, work stoppages, fires, civil disobedience or unrest, severe weather, fire or any other cause beyond the control of Company. Customer is aware that the Limitation of Liability and other provisions set forth in any existing agreement/contract, if one is in effect, or set forth above, apply to services performed and materials supplied. The terms of this agreement shall govern notwithstanding any inconsistent or additional terms and conditions in any purchase order or other document submitted by Customer.

DEVICE NOTE IMAGE APPENDICES