B Safe Security
Yarnell Security Systems
Choice Security Services
Inspection Report

Customer DOC - 32 NORTH EAST DRIVE
Address 32 Northeast DR
City Hershey, PA. 17033
Phone #
C/S Account # C55-9967

System type: Fire X Burg ____ Other ____

Period: Mths ___ Bi-Mthly ___ Qrtly ___ Semi - Ann ___ Ann X

Zone	Smoke Det	Heat Det	Water Flow	Valve Super	Pull Station	Duct Det	Pump Running	Pump Super	Room Temp F	Other	Pass	Fail
	X				X						X	

Comments Service tested: Smoke detectors, Pull stations, waterflows, Control valves, Valve tampers and Communications. Building under Construction HORN/STROBE circuit dis-connected in various Parts of Building.

Date 02/28/2023

Customer Name CAMI MILLER
Customer Signature Cami Miller

Technician Name Randy D./Warren H.
Technician Signature