



FIRE ALARM INSPECTION & TESTING REPORT

ACCOUNT #: 114905
 WORK ORDER: 291574
 DATE: 4-20-22

3hr

Name: Penn State Health		Frequency of Test:	Monthly	Bi-monthly	Quarterly	Semi-annual	Annual	
Address: 4520 Union Deposit Road		Type of Test:	NFPA 72					Technician: Ke
City: Harrisburg		State: Pa	Zip: 17011	System Location: BMT Electrical Room		Transmitter Location: 5900		
No. of Devices	No. Tested	Okay See Below						
1	1	OK						
8	8	OK						
23	23	OK						
1	1	Visual						
25	25	OK - 500 notes						
3	3	OK						
Not	263 2-78-A	OK - 5/06 mm						
1	1	Visual						
1	31 PSI	Visual						
Local Fire Dept: 3		Official Contacted: Put on test @ 11:15 AM						
Test Received at Fire Station:		Master Box Reset: Yes						
Central Station: Advant Guard		Operator Contacted: Put back in service by Alexis @ 2:15 pm						
Test Received at Station by Zone:		Master Transmitter Reset: Yes						

Remarks, Parts Used, Etc: (2) 2w-blx. Replaced 2 smoke detectors that did not work. Tested new smoke detectors and they tested ok

Yarnell Security Systems recommends Cellular Backup Systems for all systems. We understand the value of Cellular Backup and wish to have it installed.

Yes ___ No ___

Customer Signature: Alexander Bohm Technician Signature: Kevin Ke

TESTED AND FOUND OPERATIONAL ON ABOVE DATE