

CBI

CHICAGO BACKFLOW, INC.

Protecting your drinking water

Chicago Backflow, Inc.ALSP
NAPEVILLE
ELGIN708-389-5600
630-276-7070
847-760-9210ROCKFORD
LIBERTYVILLE
CHICAGO815-502-5811
847-849-0181
312-332-2182**BACKFLOW PREVENTION ASSEMBLY TEST AND CERTIFICATION REPORT**ADDRESS 30715 HIGHLAND PKWY
DOWNERS GROVE

WILKINS 975 | 457186 | 3/4 | EQUIPMENT MAKE UP

MAKE AND MODEL		SER. NO.			SIZE	SERVICE		
LOCATION		TEST RESULTS					PASS/FAIL	
NAME	DATE	CCCDW	C.V. #1	C.V. #2	RELIEF	REPAIRS/COMMENTS	PASS/FAIL	
ALAV KINDLER	8/18	XC	4324	8.4	3.2	2.8	20-40 PSI REBUILT RV	PASS
ALAV KINDLER	8/19	XC	4324	8.6	3.4	2.8	LOAF	PASS
ALAV KINDLER	8/20	XC	4324	8.8	3.2	2.8	25-45 PSI L.O.A.F	PASS
ALAV KINDLER	8/21	XC	4324	8.3	3.1	2.4	45 PSI L.O.A.F	PASS
ALAV KINDLER	8/22	XC	4324	8.4	2.2	2.8	45 PSI L.O.A.F	PASS

This document is the exclusive and proprietary property of Chicago Backflow, Inc.

CBI Corporate Office
12607 S. Laramie Avenue, Alsip, IL 60803WEB - www.chicagobackflow.com

FAX - 708-389-5632

E-mail - contact@backflow.com



BACKFLOW PREVENTER TEST REPORT

PLUMBING INSPECTION DEPARTMENT PHONE FAX

PERMIT # _____ ORIGINAL TEST
 TIME 11 AM/PM DATE 11/5/22 DISTRICT _____ RETEST PASS FAIL
 TEST KIT Wilkins TG5 CALIBRATION DATE 7/25/22
 ADDRESS 3875 Highland Parkway OWNER Leaside Property Company
 CONTACT Johanna Schmitt PHONE 312-859-2415 FAX _____
 CONTRACTOR Great Lakes Plumbing Co. PHONE 773-489-0400
 DEVICE = RP DC DCDA PVB SUPPLY PRESSURE 110 PSIG
 MFR Watts SIZE 2" MODEL# LF009M^{GT} SERIAL# 213879
 ON LINE TO Irrigation System
 EXACT LOCATION Concrete Mechanical Room

CHECK VALVE #1

CHECK VALVE #2

RELIEF VALVE

INITIAL TEST CLOSED TIGHT LEAKED PSID 8.2
 COMMENTS

CLOSED TIGHT LEAKED PSID 1.6
 COMMENTS

OPENED @ 7.4 PSID / RP ZONE
 DID NOT OPEN
 COMMENTS

FINAL TEST CLOSED TIGHT LEAKED PSID _____
 COMMENTS

CONTROL VALVE #1

CONTROL VALVE #2

TEST COCKS

TYPE Ball RW CLOSED TIGHT LEAKED COMMENTS


TYPE Ball RW CLOSED TIGHT LEAKED COMMENTS

COMPLETE
 MISSING # _____
 DAMAGED
 COMMENTS

COMMENTS new installation - DDF test

CCCDI# XC 2756 PLUMBING LICENSE# 116200
 CCCDI NAME (PRINT) Terrence Wilkins SIGNATURE

Backflow, Inc.



Chicago Backflow, Inc.

Chicago Backflow, Inc.

ALSF
NAPERVILLE
ELGIN

708-389-5600
630-276-7070
847-760-8210

ROCKFORD
LIBERTYVILLE
CHICAGO

815-502-5000
847-849-8000
312-332-2112

BACKFLOW PREVENTION ASSEMBLY TEST AND CERTIFICATION REPORT

Address 3075 HIGHLAND PKWY
DOWNSIDE GROVE, IL

WAF 957

UF 1714

4"

DOMESTIC

MAKE AND MODEL		SER. NO.		SIZE	SERVICE		
LOCATION							
NAME	DATE	CCCD#	C.V. #1	C.V. #2	RELIEF	REPAIRS/COMMENTS	PASS/FAIL
ALAN KILMORER	8/18/21	XC	4324	10.8	3.2 2.8	6ops1 REPLACES 5/1/14-1895	PASS
ALAN KILMORER	8/14/22	XC	4324	10.8	3.2 2.6	6ops1	PASS

This document is the exclusive and proprietary property of Chicago Backflow, Inc.

CBI Corporate Office

12607 S. Laramie Avenue, Alsip, IL 60803

WEB - www.chicagobackflow.com

FAX - 708-389-5632

E-mail - contact@backflow.com



Chicago Backflow, Inc.

ALSIP
NAPERVILLE
ELGIN

708-389-5600
630-276-7070
847-750-9210

ROCKFORD-
LIBERTYVILLE
CHICAGO

815-502-5001
847-849-8101
312-332-2112

BACKFLOW PREVENTION ASSEMBLY TEST AND CERTIFICATION REPORT

Address 3075 HIGHLAND PARKWAY
DOWNERS GROVE, IL

AMES 20055 | 38M0323 | 8"

FILE PROTECTION

MAKE AND MODEL		SER. NO.			SIZE	SERVICE	
LOCATION		Pump Room					
NAME	DATE	COCDM	C.V. #1	C.V. #2	RELIEF	REPAIRS/COMMENTS	PASS/FAIL
AAV KINOWER	8/17/19	XC 4324	3.0	2.6	X	60psi	PASS
AAV KINOWER	8/17/20	XC 4324	3.6	2.0	X	65psi	PASS
AAV KINOWER	8/18/21	XC 4324	3.2	2.4	X	60psi	PASS
AAV KINOWER	8/4/22	XC 4324	3.4	2.6	X	65psi	PASS

This document is the exclusive and proprietary property of Chicago Backflow, Inc.

CBI Corporate Office
12607 S. Laramie Avenue, Alsip, IL 60803

WEB - www.chicagobackflow.com

FAX - 708-389-5632

E-mail - contact@backflow.com

CBI

CHICAGO BACKFLOW, INC.

Protecting your drinking water

Chicago Backflow, Inc.ALSIP
NAPERVILLE
ELGIN708-389-5600
630-276-7070
847-760-9210ROCKFORD
LIBERTYVILLE
CHICAGO815-502-5001
847-849-8101
312-332-2112**BACKFLOW PREVENTION ASSEMBLY TEST AND CERTIFICATION REPORT**Address **3075 HIGHLAND PARKWAY
DOWNERS GROVE, IL****WATTS 007 98564 3/4 AFE BYPASS**

MAKE AND MODEL		SER. NO.		SIZE	SERVICE		
LOCATION		Pump Room					
NAME	DATE	CCCDM	C.V. #1	C.V. #2	RELIEF	REPAIRS/COMMENTS	PASS/FAIL
ALAN KIMMOR	8/7/19	XC 4324	1.8	2.0	X	60psi	PASS
ALAN KIMMOR	8/17/20	XC 4324	1.9	2.0	X	60psi	PASS
ALAN KIMMOR	8/18/21	XC 4324	2.2	2.2	X	60psi REPLACED #4 T.C.	PASS
ALAN KIMMOR	8/4/22	XC 4324	2.0	2.0	X	60psi	PASS

This document is the exclusive and proprietary property of Chicago Backflow, Inc.

CBI Corporate Office
12607 S. Laramie Avenue, Alsip, IL 60803WEB - www.chicagobackflow.com

FAX - 708-389-5632

E-mail - contact@backflow.com