

Naperville, City of

Backflow Prevention Assembly Test and Maintenance Report



Customer Information

Name RIVERS EDGE PLAZA
Contact
Address 235 S MAIN ST HM
NAPERVILLE, IL 60540
Residential ☐ **Non-Residential** ☒

Assembly Information

Type RP **Model** 909
Size 0.75 **Serial#** 344909
Manufacturer Watts **Hazard** Domestic
Location Behind unit 205; Mech rm
Hazard ID 4494387
New Installation ☐ **Existing** ☒ **Replacement** ☐
If replacement: Old Model # **Old Serial #**

Assembly Test Report

Initial Test		
Check Valve #1 7.6 <input checked="" type="checkbox"/> Closed Tight <input type="checkbox"/> Leaked	Check Valve #2 6.8 <input checked="" type="checkbox"/> Closed Tight <input type="checkbox"/> Leaked	Relief Valve 2.6 <input checked="" type="checkbox"/> Opened <input type="checkbox"/> Did Not Open
Final Test		

Repairs and Notes: Rebuilt Device 1st and 2nd checks

Tester Information

The backflow prevention assembly detailed on this form has been tested and maintained as required by codes and regulations, is certified to be true & accurate, and is operating within acceptable parameters at time of testing. * Only Manufacturer's replacement parts have been used. **Test records must be kept for a minimum of three years

Tester Name Gary Dohogne - B&A Plumbing Inc
Tester License Expiration 06/30/2024
Certification # XC5931
Test Kit Mfr & Mod # Midwest 845-5
Serial # 09220341
Company B&A Plumbing Inc
Address 619 Estes Avenue
Schaumburg, IL 60193
Phone (847) 985-2444

Test Kit Expiration Date

09/15/2023

Potable Kit ☒

Non-Potable Kit ☐

PASS

Test Date: 09/14/2023

Date Submitted: 09/15/2023