

**FIRE & SECURITY SPECIALIST**

15941 HARLEM AVE # 351  
 TINLEY PARK, IL 60477-1609  
 (773) 401-9937

Report Number  
**4399423**

**Occupancy Information**

|  |   |
|--|---|
| <b>Name:</b><br>LAKE POINT TOWERS CONDO<br>505 N LAKE SHORE DR<br>CHICAGO, IL 60611-3427 | <b>Contact:</b><br>Responsible Person<br>JIM STECKO<br>LAKE POINT TOWER CONDO ASSOCIATION<br>505 N. LAKE SHORE DRIVE<br>CHICAGO, IL 60611 |
|  | <b>Phone:</b><br>(312) 645-8802   |

**Chicago Fire Alarm Inventory****Fire Alarm**

|   |  |
|---|--|
| <b>Service Date</b><br>October 14, 2022   | <b>Report Number:</b><br>4399423               |
| <b>AHJ:</b><br>CHICAGO FIRE DEPARTMENT/FIRE<br>PREVENTION BUREAU<br>444 N DEARBORN ST<br>FL 2<br>CHICAGO, IL 60654-5602 | <b>Status:</b><br>Compliant                    |
| <b>Phone:</b><br>(312) 744-4723   | <b>Report Type:</b><br>L - (Annual) Fire Alarm |
| <b>Reviewed by AHJ:</b> No  | <b>Code Reference:</b><br>NFPA 72              |

**Inspection & Testing Agency Information**

|  |                                  |
|--|----------------------------------|
| <b>Name:</b><br>FIRE & SECURITY SPECIALIST<br>15941 HARLEM AVE # 351<br>TINLEY PARK, IL 60477-1609 | <b>Phone:</b><br>(773) 401-9937  |
|  | <b>Emergency Phone:</b>          |
|  | <b>Email:</b><br>bill@fssinc.biz |

**Inspector/Tester Information**

|                                |                                 |
|--------------------------------|---------------------------------|
| <b>Name:</b><br>WILLIAM PURSEL | <b>Phone:</b><br>(773) 401-9937 |
|--------------------------------|---------------------------------|

**Contact Information****Problems Found**

| Question #         | Code Ref(s) | Question | Answer | Impairment | Corrected |
|--------------------|-------------|----------|--------|------------|-----------|
| No problems found. |             |          |        |            |           |

PLEASE NOTE: All deficiencies must be typed into the section(s) provided below. Only one deficiency is permitted per row. Click the "add row" button to add sections for reporting additional deficiencies. If you have corrected a deficiency during the time of inspection: Click on the corrected button to the right of the noted deficiency in the highlighted section above. An attached copy of the original ITM report is required for submission of this report type (denoted by a red asterisk).

**Monitoring Entity**

| Question # | Code Ref(s) | Question                       | Answer       |
|------------|-------------|--------------------------------|--------------|
|            |             | Is fire alarm being monitored? | Yes          |
|            |             | Contact:                       | Emergency 24 |
|            |             | Phone number:                  | 18008773624  |
|            |             | Monitoring account ref. No.:   | 505          |

**Alarm Details**

| Question # | Code Ref(s) | Question                   | Answer       |
|------------|-------------|----------------------------|--------------|
|            |             | Transmission type?         | Digital      |
|            |             | Control unit manufacturer? | Gamewell FCI |

|  |            |
|--|------------|
| Model No.:   | E3         |
| Circuit styles?                                      | B & 6      |
| Number of Circuits?                                  | 102        |
| Software rev.:                                       | N/A        |
| Last date system had any service performed?          | 09/28/2022 |
| Last date any software or configuration was revised? | 08/09/2022 |

**Alarm-Initiating Devices and Circuit Information**

| Question # | Code Ref(s) | Question   | Answer                    |
|------------|-------------|--|---------------------------|
|            |             | Alarm-Initiating Devices and Circuit Information | Quantity<br>Circuit Style |
|            |             | Manual Fire Alarm Boxes                          |                           |
|            |             | Ion Detectors                                    |                           |
|            |             | Photo Detectors                                  | 1,165.00 6                |
|            |             | Duct Detectors                                   | 4.00 6                    |
|            |             | Heat Detectors                                   | 32.00 6                   |
|            |             | Waterflow Switches                               | 11.00 6                   |
|            |             | Supervisory Switches                             | 21.00 6                   |
|            |             | Alarm verification feature is enabled?           | No                        |

**Alarm Notification Appliances & Circuit Information**

| Question # | Code Ref(s) | Question                                      | Answer        |
|------------|-------------|---|---------------|
|            |             | Quantity                                      | Circuit Style |
|            |             | Bells   | 3.00 B        |
|            |             | Horns   |               |
|            |             | Chimes  |               |
|            |             | Strobes                                       | 670.00 B      |
|            |             | Speakers                                      | 670.00 B      |
|            |             | No. of alarm notification appliance circuits? | 96            |
|            |             | Are circuits monitored for integrity?         | Yes           |

**Supervisory Signal-Initiating Devices & Circuit Information**

| Question # | Code Ref(s) | Question         | Answer        |
|------------|-------------|------------------|---------------|
|            |             | Quantity         | Circuit Style |
|            |             | Building Temp.   |               |
|            |             | Site Water Temp. |               |
|            |             | Site Water Level |               |

|                            |      |   |
|----------------------------|------|---|
| Fire Pump Power            | 3.00 | B |
| Fire Pump Running          | 3.00 | B |
| Fire Pump Auto Position    |      |   |
| Fire Pump or Pump          | 3.00 | B |
| Controller Trouble         |      |   |
| Fire Pump Running          |      |   |
| Generator In Auto Position |      |   |
| Generator or Controller    |      |   |
| Trouble                    |      |   |
| Switch Transfer            |      |   |
| Generator Engine Running   |      |   |

**Signaling Line Circuits**

| Question # | Code Ref(s) | Question   | Answer           |
|------------|-------------|--|------------------|
|            |             | Quantity of signaling line circuits connected to system?   | 14               |
|            |             | Style of signaling line circuits connected to system?  | 6                |
|            |             | Battery type?  | Sealed Lead-Acid |
|            |             | Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply: | N/A              |

**Testing & Inspections**

| Question #                | Code Ref(s) | Question   | Answer   |
|---------------------------|-------------|--|--|
|                           |             | Prior to any testing notifications are made to monitoring entity, building occupants, building management? | Yes  |
| System Test & Inspections | Visual      | Functional   | Passed visual and functional test & inspection |
| Control Unit              | Yes         | Yes  | Yes  |
| Interface Equipment       | Yes         | Yes  | Yes  |
| Lamps/LEDS                | Yes         | Yes  | Yes  |
| Fuses                     | Yes         | Yes  | Yes  |
| Primary Power Supply      | Yes         | Yes  | Yes  |
| Trouble Signals           | Yes         | Yes  | Yes  |
| Disconnect Switches       | Yes         | Yes  | Yes  |
| Ground-Fault Monitoring   | Yes         | Yes  | Yes  |

|                   |     |     |     |
|-------------------|-----|-----|-----|
| Battery Condition | Yes | Yes | Yes |
| Load Voltage      | Yes | Yes | Yes |
| Discharge Test    | No  | No  | N/A |
| Charger Test      | No  | No  | N/A |
| Specific Gravity  | No  | No  | N/A |
| Audible           | Yes | Yes | Yes |
| Visible           | Yes | Yes | Yes |
| Speakers          | Yes | Yes | Yes |
| Voice Clarity     | Yes | Yes | Yes |

| System                 | Quantity Tested | Factory Setting | Measured Setting | Passed Visual & Functional Test |
|------------------------|-----------------|-----------------|------------------|---------------------------------|
| <b>Devices</b>         |                 |                 |                  |                                 |
| Pull Stations          |                 |                 |                  | N/A                             |
| Ion Detectors          |                 |                 |                  | N/A                             |
| Photo Detectors        | 1,165.00        |                 |                  | Yes                             |
| Duct Detectors         | 4.00            |                 |                  | Yes                             |
| Heat Detectors         | 32.00           |                 |                  | Yes                             |
| Waterflow Switches     | 11.00           |                 |                  | Yes                             |
| Tamper Switches        | 21.00           |                 |                  | Yes                             |
| Pressure Switches      | 2.00            |                 |                  | Yes                             |
| Low Air                | 2.00            |                 |                  | Yes                             |
| Bells/Horns/Chimes     | 3.00            |                 |                  | Yes                             |
| Strobes                |                 |                 |                  | N/A                             |
| Speakers               |                 |                 |                  | N/A                             |
| Speaker/Strobes        | 670.00          |                 |                  | Yes                             |
| Automatic Door Release |                 |                 |                  | N/A                             |
| Automatic Door Unlocks |                 |                 |                  | N/A                             |

|                |       |     |
|----------------|-------|-----|
| Fire Dampers   |       | N/A |
| Beam Detectors |       | N/A |
| Annunciators   | 2.00  | Yes |
| Phone Sets     | 47.00 | Yes |
| Phone Jacks    |       | N/A |
| Call-In-Signal |       | N/A |

**Supervising Station Monitoring (If Monitored)**

| Question # | Code Ref(s) | Question                       | Answer |
|------------|-------------|--------------------------------|--------|
|            |             | Fire alarm is being monitored? | Yes    |
|            |             | Alarm signal?                  | Yes    |
|            |             | Alarm restoration?             | Yes    |
|            |             | Trouble signal?                | Yes    |
|            |             | Supervisory signal             | Yes    |
|            |             | Supervisory restoration?       | Yes    |

**Conclusion**

| Question # | Code Ref(s) | Question   | Answer |
|------------|-------------|--|--------|
|            |             | System restored to normal operation?   | Yes    |
|            |             | Notifications have been made that testing is complete to the building management, monitoring agency, building occupants? | Yes    |

Do you have additional deficiencies to list? Please review the issues/corrections section (bottom of report) prior to listing additional deficiencies. The question below is for all unrecorded deficiencies.

Enter one deficiency per row Deficiency found:

1.