

**ELEVATOR INSPECTION FORM**

**I 19904**



**Elevator Inspection Service**

Est. 1976



745 McClintock Drive, Suite 235, Burr Ridge, IL 60527 • Phone 630-323-6541 / Fax 630-323-7149

Date 11-2-2023  
 Code Edition: ASME A17.1 1996 A17.3  
 V/T/C Wheaton  
 ID # #1 Pass Convey # T006916  
 Inspection & Test  Routine  Periodic  Acceptance  
 Power Traction (FLPT) 11-23  
 Capacity 2500 Em Ph PASS  
 Em Light PASS

Address 120 E Liberty Dr Unit #1 Pass  
 Bldg. Name Wheaton Properties Make Kane  
 Bldg. Rep. \_\_\_\_\_ Speed 150 fpm  
 Phone No. \_\_\_\_\_

	OK	NG	NA		OK	NG	NA	
<b>1. ELEVATOR-INSIDE OF CAR</b>					<b>3. ELEVATOR-TOP OF CAR</b>			
1.1 Door reopening device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.24 (T) AC drives from a DC source	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.2 Stop switches	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.25 (T) Traction sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.3 Operating control devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.26 (T) Secondary & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.4 Sills & car floor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.27 (T) Rope fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.5 Car lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.28 (T) Terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.6 Car emergency signal-lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.29 (T) Car & counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.7 Car door or gate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.30 Hydraulic power unit	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.8 Door closing force	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.31 Relief valves	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.9 Power closing of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.32 Control valve	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.10 Power opening of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.33 Tanks	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.11 Car vision panels & glass car doors	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.34 Flexible hydr hose & fitting assemblies	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.12 Car enclosure	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.35 Supply line & shutoff valve	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.13 Emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.36 Hydraulic cylinders	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.14 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.37 Pressure switch	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.15 Signs & operating device symbols	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.38 Robed water hydraulic elevators	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.16 Rated load, platform area, & data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.39 Low oil protection	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
1.17 Standby power operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.40 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.18 Restricted opening of car or hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.41 Maintenance records	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.19 Car Ride	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.42 Static control	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<b>2. ELEVATOR-MACHINE ROOM</b>					<b>4. ELEVATOR-OUTSIDE HOISTWAY</b>			
2.1 Access to machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.1 Car platform guard	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.2 Headroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.2 Hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.3 Lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.3 Vision panels	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
2.4 Machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.4 Hoistway door locking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.5 Housekeeping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.5 Access to hoistway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.6 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.6 Power closing of hoistway doors	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
2.7 Fire extinguisher	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.7 Sequence operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.8 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.8 Hoistway enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.9 Guarding of exposed auxiliary equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.9 Elevator Parking devices	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
2.10 #ing of elevators, machines, disconnects	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.10 Emergency doors in blind hoistways	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
2.11 Disconnecting means & control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.11 (T) Separate counterweight hoistway	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
2.12 Controller wiring, fuses, grounding, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.12 Standby power selection switch	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
2.13 Governor, overspeed switch, & seal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.13 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.14 Code data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>5. ELEVATOR-PIT</b>				
2.15 (T) Static control	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5.1 Pit access, lighting, stop switch, & condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.16 (T) Overhead beam & fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.2 Bottom clearance, runby & min. refuge space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.17 (T) Drive machine brake	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.3 (T) Final & emergency terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.18 (T) Traction drive machines	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.19 (T) Gears, bearings, & flexible coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.5 Traveling cables	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.20 (T) Winding drum mach & slack cable dev	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5.6 Governor-rope tension devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.21 (T) Belt or chain-drive machine	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5.7 Car Frame & platform	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.22 (T) Motor generator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5.8 Car safeties & guiding memb-incl roped-hydr elev(*)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2.23 (T) Absorption of regenerated power	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5.9 (T) Buffers & emerg terminal speed limiting devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
				5.10 (T) Compensating chains, ropes & sheaves	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
				5.11 Plunger & cylinder	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
				5.12 Car Buffer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
				5.13 Guiding members	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
				5.14 Supply piping	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
				<b>6. ELEVATOR FIRE SERVICE</b>				
				6.1 PH 1 ONLY	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
				6.2 PH 1 & PH 2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
				F.A.I.D. Date <u>11/2/23</u>				
				<b>7. ELEVATOR TACTILE IDENTIFICATION</b>				
				(410 ILCS 30/1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

**COMMENTS:**

OK - meets requirement NG - insert number to identify comment NA - not applicable (T) Traction Cars (\*) installed under A17 1b-1989 and later editions

RE-INSPECTION FOR PERIODIC FAILURE 8-2-23  
 PHONE GOOD  
 CAT-5 PERFORMED

THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY. THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.


FAIL - RE-INSPECT IN \_\_\_\_\_ DAYS  
 PASS - CONDITION GOOD -  
 Approved for Certificate

ROME / SEAN  
 Elevator Co./Building Representative  
 Elev Co Lic # IL \_\_\_\_\_  
 Elev Mech Lic # IL 02845

[Signature]  
 Inspector's Signature  
 Inspector QEI # C-6679  
 Inspector's Lic # IL 00370

# PERIODIC TESTS OF ELECTRIC ELEVATORS

T40227

 <b>EIS / Elevator Inspection Service</b> Phone 630.323.6541 • Fax 630.323.7149	Date <u>11 / 2 / 2023</u>
	V-T-C <u>WHEATON</u>
	State of IL Reg. I.D.# <u>T006916</u>
	Date of Last 5 Year Test <u>11 / 2 / 23</u>
Bldg. Name: <u>WHEATON PROPERTIES</u>	P.O.# <u>4545848751</u>
Address: <u>120 E. LIBERTY DR.</u>	Bldg. I.D. <u>#1 PASS</u>
Bldg. Phone:	<input checked="" type="checkbox"/> Pass / Freight / Service - Make: <u>KONE</u>
Owner / Manager Name	Speed: <u>150</u> Capacity: <u>2500</u>

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			✓
Safeties	8.6.4.19.2	✓		
Governors	8.6.4.19.3	✓		
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			✓
Normal & Final Terminal Stopping Devices	8.6.4.19.5	✓		
Firefighters' Emergency Operation	8.6.4.19.6	✓		
Standby or Emergency Power Operation	8.6.4.19.7			
Power Operation of Door System	8.6.4.19.8	✓		
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			✓
E/E/PES Electrical Protective Devices	8.6.4.19.10	✓		

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1	✓		
Governors	8.6.4.20.2	✓		
Oil Buffers	8.6.4.20.3			✓
Braking System	8.6.4.20.4	✓		
Emergency and Standby Power Operation	8.6.4.20.5			
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6	✓		
Power Opening of Doors	8.6.4.20.7	✓		
Leveling Zone & Leveling Speed	8.6.4.20.8	✓		
Inner Landing Zone	8.6.4.20.9			✓
Emergency Stopping Distance	8.6.4.20.10	✓		

GOVERNOR & SAFETY TEST (Rule 1002.3A)									
Gov. Trip Spd Prev.	Present	<u>240</u>	fpm	Gov. Pull Thru	<u>200</u>				
O.S. Trip Spd Prev.	Present	<u>205</u>	fpm	Gov. Pull Out					
Weight Test	No Load	Full Load	✓	Capacity	<u>2500</u>	Length of Slide- Left	<u>3"</u>	Right	<u>3"</u>
Was Load & Speed Test Satisfactory?	Yes	✓	No	Brake at 125%	Yes	✓	No		
Safety Type	Instant.	Flex Guide	Other	Was Governor Sealed	Yes	✓	No		
		✓		Was Governor Tagged	Yes	✓	No		

OIL BUFFER TEST (Rule 100.2A) Annual			
Load & Speed Test Satisfactory?	Yes	<del>No</del>	Oil Level & Return Test Satisfactory?
			Yes <del>No</del>

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
# of Landings	<u>6</u>			
Machine Room	2.27.3.2.1.(a)			
Hoistway	2.27.3.2.1.(b)			
Pit	2.27.3.2.1.(c)			

Comments: FAID TEST COMPLETED - PASS

Signature of Inspector <u>[Signature]</u> <u>C-6679</u> Inspector's State of Illinois License # <u>1L06320</u>	Signature of Person Conducting Test & State License # <u>SEAN</u> <u>1L02845</u> Employed by (Company Name) <u>KONE</u>
---	--

**ELEVATOR INSPECTION FORM**

**I 19905**



**Elevator Inspection Service**

Est. 1976



745 McClintock Drive, Suite 235, Burr Ridge, IL 60527 • Phone 630-323-6541 / Fax 630-323-7149

Date 11-2-2023  
 Code Edition: ASME A17.1 1996 A17.3  
 V/T/C Wheaton  
 ID # #2 Pass Convey # T006915  
 Inspection & Test  Routine  Periodic  Acceptance  
 Power Traction FL/PT 11-23  
 Capacity 2500 Em Ph PASS  
 Em Light PASS

Address 120 E Liberty Dr Unit #2 Pass  
 Bldg. Name Wheaton Properties Make Kone  
 Bldg. Rep. \_\_\_\_\_ Speed 150 fpm  
 Phone No. \_\_\_\_\_

	OK	NG	NA		OK	NG	NA
<b>1. ELEVATOR-INSIDE OF CAR</b>				2.24 (T) AC drives from a DC source	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.1 Door reopening device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.25 (T) Traction sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.2 Stop switches	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.26 (T) Secondary & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.3 Operating control devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.27 (T) Rope fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.4 Sills & car floor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.28 (T) Terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.5 Car lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.29 (T) Car & counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.6 Car emergency signal-lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.30 Hydraulic power unit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.7 Car door or gate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.31 Relief valves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.8 Door closing force	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.32 Control valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.9 Power closing of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.33 Tanks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.10 Power opening of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.34 Flexible hydr hose & fitting assemblies	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.11 Car vision panels & glass car doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.35 Supply line & shut-off valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.12 Car enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.36 Hydraulic cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.13 Emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.37 Pressure switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.14 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.38 Robed water hydraulic elevators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.15 Signs & operating device symbols	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.39 Low oil protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.16 Rated load, platform area, & data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.40 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.17 Standby power operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.41 Maintenance records	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.18 Restricted opening of car or hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.42 Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
1.19 Car Ride	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>3. ELEVATOR-TOP OF CAR</b>			
<b>2. ELEVATOR-MACHINE ROOM</b>				3.1 Top-of-car stop switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.1 Access to machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.2 Car top light & outlet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.2 Headroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.3 Top-of-car operating device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.3 Lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.4 Machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.5 Clearance, refuge space standard railing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.5 Housekeeping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.6 Final & emerg terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.6 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.7 Car leveling & anticreep devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.7 Fire extinguisher	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.8 Top emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.8 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.9 Floor & emerg identification numbering	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.9 Guarding of exposed auxiliary equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.10 Hoistway construction	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.10 #ing of elevators, machines, disconnects	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.11 Hoistway smoke control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.11 Disconnecting means & control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.12 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.12 Controller wiring, fuses, grounding, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.13 Windows, projections, recesses, & setbacks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.13 Governor, overspeed switch, & seal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.14 Hoistway clearances	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.14 Code data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.15 Multiple hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.15 (T) Static control	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3.16 Traveling cables & junction boxes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.16 (T) Overhead beam & fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.17 Door & gate equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.17 (T) Drive machine brake	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.18 Car frame & stiles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.18 (T) Traction drive machines	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.19 Guide rails fastening & equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.19 (T) Gears, bearings, & flexible coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.20 Governor rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.20 (T) Winding drum mach & slack cable dev	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3.21 Governor releasing carrier	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.21 (T) Belt or chain-drive machine	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3.22 Wire rope fastening & hitch plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.22 (T) Motor generator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3.23 Suspension rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.23 (T) Absorption of regenerated power	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3.24 (T) Top counterweight clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.25 (T) Car, overhead, & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.26 (T) Broken rope, chain, or tape switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.27 Crosshead data plate & rope data tags	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.28 Counterweight & counterweight buffer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.29 Counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.30 Speed test	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				3.31 Slack rope device-roped hydr elevs (*)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				3.32 Traveling sheave-roped hydr elevs (*)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				3.33 (T) Compensating ropes & chains	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				<b>4. ELEVATOR-OUTSIDE HOISTWAY</b>			
				4.1 Car platform guard	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.2 Hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.3 Vision panels	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.4 Hoistway door locking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.5 Access to hoistway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.6 Power closing of hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.7 Sequence operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.8 Hoistway enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.9 Elevator Parking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.10 Emergency doors in blind hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.11 (T) Separate counterweight hoistway	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				4.12 Standby power selection switch	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				4.13 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				<b>5. ELEVATOR-PIT</b>			
				5.1 Pit access, lighting, stop switch, & condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.2 Bottom clearance, runby & min. refuge space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.3 (T) Final & emergency terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.5 Traveling cables	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.6 Governor-rope tension devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.7 Car Frame & platform	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.8 Car safeties & guiding memb-incl roped-hydr elev(*)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.9 (T) Buffers & emerg terminal speed limiting devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.10 (T) Compensating chains, ropes & sheaves	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				5-11 Plunger & cylinder	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.12 Car Buffer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.13 Guiding members	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.14 Supply piping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				<b>6. ELEVATOR FIRE SERVICE</b>			
				6.1 PH 1 ONLY	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				6.2 PH 1 & PH 2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				F.A.I.D. Date <u>11-2-23</u>			
				<b>7. ELEVATOR TACTILE IDENTIFICATION</b>			
				(410 ILCS 30/1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**COMMENTS:** OK - meets requirement NG - insert number to identify comment NA - not applicable (T) Traction Cars (\*) installed under A17 1b-1989 and later editions

*RE-INSPECTION FOR PERIODIC FAILURE 8-2-23*

*PHONE GOOD*

*CAR. 5 PERFORMED*

THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY. THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.

FAIL - RE-INSPECT IN \_\_\_\_\_ DAYS

PASS - CONDITION GOOD -

Approved for Certificate

KONE / SEAN  
 Elevator Co./Building Representative

Elev Co Lic # IL \_\_\_\_\_

Elev Mech Lic # IL 02845

[Signature]  
 Inspector's Signature


Inspector QEI # C-6679

Inspector's Lic # IL 06320



# PERIODIC TESTS OF ELECTRIC ELEVATORS

T40224

 <b>EIS / Elevator Inspection Service</b> Phone 630.323.6541 • Fax 630.323.7149	Date <u>11 / 2 / 2023</u>
	V-T-C <u>WHEATON</u>
Bldg. Name: <u>WHEATON PROPERTIES</u>	State of IL Reg. I.D.# <u>T006915</u>
	Date of Last 5 Year Test <u>11 / 2 / 23</u>
Address: <u>120 E. LIBERTY DR.</u>	P.O.# <u>4545848751</u>
Bldg. Phone:	Bldg. I.D. <u>#2 PASS</u>
Owner / Manager Name	<u>Pass</u> / Freight / Service - Make: <u>KONE</u>
	Speed: <u>150</u> Capacity: <u>2500</u>

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			✓
Safeties	8.6.4.19.2	✓		
Governors	8.6.4.19.3	✓		
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			✓
Normal & Final Terminal Stopping Devices	8.6.4.19.5	✓		
Firefighters' Emergency Operation	8.6.4.19.6	✓		
Standby or Emergency Power Operation	8.6.4.19.7	—		
Power Operation of Door System	8.6.4.19.8	✓		
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			✓
E/E/PES Electrical Protective Devices	8.6.4.19.10	✓		

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1	✓		
Governors	8.6.4.20.2	✓		
Oil Buffers	8.6.4.20.3			✓
Braking System	8.6.4.20.4	✓		
Emergency and Standby Power Operation	8.6.4.20.5	—		
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6	✓		
Power Opening of Doors	8.6.4.20.7	✓		
Leveling Zone & Leveling Speed	8.6.4.20.8	✓		
Inner Landing Zone	8.6.4.20.9			✓
Emergency Stopping Distance	8.6.4.20.10	✓		

<b>GOVERNOR &amp; SAFETY TEST (Rule 1002.3A)</b>										
Gov. Trip Spd	Prev.	Present	<u>235</u>	fpm	Gov. Pull Thru	<u>220</u>				
O.S. Trip Spd	Prev.	Present	<u>205</u>	fpm	Gov. Pull Out					
Weight Test	No Load	Full Load	✓		Capacity	<u>2500</u>	Length of Slide—	Left <u>3"</u>	Right <u>3"</u>	
Was Load & Speed Test Satisfactory?	Yes	✓	No		Brake at 125%	Yes	✓	No		
Safety Type	Instant.	Flex Guide	Other		Was Governor Sealed	Yes	✓	No		
		✓			Was Governor Tagged	Yes	✓	No		

<b>OIL BUFFER TEST (Rule 100.2A) Annual</b>			
Load & Speed Test Satisfactory?	Yes	✓	No
Oil Level & Return Test Satisfactory?	Yes	✓	No

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
# of Landings	<u>6</u>			
Machine Room	2.27.3.2.1.(a)			
Hoistway	2.27.3.2.1.(b)			
Pit	2.27.3.2.1.(c)			

Comments: FAID TEST COMPLETED - PASS

Signature of Inspector <u>[Signature]</u> QEI # <u>C-6679</u> Inspector's State of Illinois License # <u>1L06320</u>	Signature of Person Conducting Test & State License # <u>SEAN 1L02845</u> Employed by (Company Name) <u>KONE</u>
---	---

# ELEVATOR INSPECTION FORM

I 19906



Elevator Inspection Service

Est. 1976



745 McClintock Drive, Suite 235, Burr Ridge, IL 60527 • Phone 630-323-6541 / Fax 630-323-7149

Date 11-3-2023  
 Code Edition: ASME A 17.1 \_\_\_\_\_ A17.3 \_\_\_\_\_  
 V/T/C Wheaton  
 ID # #3 Pass Convey # T006917  
 Inspection & Test  Routine  Periodic  Acceptance  
 Power Traction FL/PT 11-23  
 Capacity 3500 Em Ph PASS  
 Em Light PASS

Address 120 E Liberty Dr Unit #3 Pass  
 Bldg. Name Wheaton Properties Make Kone  
 Bldg. Rep. \_\_\_\_\_ Speed 150 fpm  
 Phone No. \_\_\_\_\_

	OK	NG	NA		OK	NG	NA		OK	NG	NA	
<b>1. ELEVATOR-INSIDE OF CAR</b>												
1.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.24	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) AC drives from a DC source	3.25	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Car, overhead, & deflector sheaves
1.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.25	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) Traction sheaves	3.26	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Broken rope, chain, or tape switch
1.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.26	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) Secondary & deflector sheaves	3.27	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Crosshead data plate & rope data tags
1.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.27	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) Rope fastenings	3.28	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Counterweight & counterweight buffer
1.5	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.28	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) Terminal stopping devices	3.29	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Counterweight safeties
1.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.29	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) Car & counterweight safeties	3.30	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Speed test
1.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.30	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydraulic power unit	3.31	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Slack rope device-roped hydr elevs (*)
1.8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.31	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Relief valves	3.32	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Traveling sheave-roped hydr elevs (*)
1.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.32	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Control valve	3.33	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Compensating ropes & chains
1.10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.33	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Tanks	<b>4. ELEVATOR-OUTSIDE HOISTWAY</b>			
1.11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.34	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Flexible hydr hose & fitting assemblies	4.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Car platform guard
1.12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.35	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Supply line & shutoff valve	4.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Hoistway doors
1.13	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.36	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydraulic cylinders	4.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Vision panels
1.14	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.37	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pressure switch	4.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Hoistway door locking devices
1.15	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.38	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Robed water hydraulic elevators	4.5	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Access to hoistway
1.16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.39	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Low oil protection	4.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Power closing of hoistway doors
1.17	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.40	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Inspection control	4.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sequence operation
1.18	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.41	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maintenance records	4.8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Hoistway enclosure
1.19	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.42	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Static control	4.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Elevator Parking devices
<b>2. ELEVATOR-MACHINE ROOM</b>												
2.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<b>3. ELEVATOR-TOP OF CAR</b>				3.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Top-of-car stop switch
2.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Car top light & outlet	4.10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Emergency doors in blind hoistways
2.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Top-of-car operating device	4.11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Separate counterweight hoistway
2.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Normal terminal stopping devices	4.12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Standby power selection switch
2.5	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Clearance, refuge space standard railing	4.13	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Inspection control
2.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.5	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Final & emerg terminal stopping devices	<b>5. ELEVATOR-PIT</b>			
2.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Car leveling & anticreep devices	5.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Pit access, lighting, stop switch, & condition
2.8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Top emergency exit	5.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Bottom clearance, runby & min. refuge space
2.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Floor & emerg identification numbering	5.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Final & emergency terminal stopping devices
2.10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hoistway construction	5.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Normal terminal stopping devices
2.11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hoistway smoke control	5.5	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Traveling cables
2.12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pipes, wiring & ducts	5.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Governor-rope tension devices
2.13	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Windows, projections, recesses, & setbacks	5.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Car Frame & platform
2.14	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.13	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hoistway clearances	5.8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Car safeties & guiding memb-incl roped-hydr elev(*)
2.15	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.14	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Multiple hoistways	5.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Buffers & emerg terminal speed limiting devices
2.16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.15	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Traveling cables & junction boxes	5.10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	(T) Compensating chains, ropes & sheaves
2.17	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Door & gate equipment	5.11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Plunger & cylinder
2.18	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.17	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Car frame & stiles	5.12	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Car Buffer
2.19	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.18	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Guide rails fastening & equipment	5.13	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Guiding members
2.20	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.19	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Governor rope	5.14	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Supply piping
2.21	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.20	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Governor releasing carrier	<b>6. ELEVATOR FIRE SERVICE</b>			
2.22	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.21	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Wire rope fastening & hitch plate	6.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	PH 1 ONLY
2.23	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.22	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Suspension rope	6.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	PH 1 & PH 2
				3.23	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(T) Top counterweight clearance				F.A.I.D. Date <u>11/2/23</u>
				3.24	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<b>7. ELEVATOR TACTILE IDENTIFICATION</b>			
												(410 ILCS 30/1)

COMMENTS: OK - meets requirement NG - insert number to identify comment NA - not applicable (T) Traction Cars (\*) installed under A17 1b-1989 and later editions

THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY. THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.


FAIL - RE-INSPECT IN \_\_\_\_\_ DAYS  
 PASS - CONDITION GOOD -  
 Approved for Certificate

KONE / SEAN  
 Elevator Co./Building Representative  
 Elev Co Lic # IL \_\_\_\_\_  
 Elev Mech Lic # IL 02845

[Signature]  
 Inspector's Signature  
 Inspector QEI # C-6679  
 Inspector's Lic # IL 06320

# PERIODIC TESTS OF ELECTRIC ELEVATORS

T40225

 <b>EIS / Elevator Inspection Service</b> Phone 630.323.6541 • Fax 630.323.7149	Date	11 / 3 / 2023
	V - T - C	WHEATON
Bldg. Name: WHEATON PROPERTIES Address: 120 E. LIBERTY DR. Bldg. Phone: Owner / Manager Name	State of IL Reg. I.D.#	T006917
	Date of Last 5 Year Test	11 / 3 / 23
	P.O.#	4545848751
	Bldg. I.D.	# 3 PASS
	Pass Freight / Service - Make:	KONE
	Speed:	150 Capacity: 3500

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			✓
Safeties	8.6.4.19.2	✓		
Governors	8.6.4.19.3	✓		
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			✓
Normal & Final Terminal Stopping Devices	8.6.4.19.5	✓		
Firefighters' Emergency Operation	8.6.4.19.6	✓		
Standby or Emergency Power Operation	8.6.4.19.7	✓		
Power Operation of Door System	8.6.4.19.8	✓		
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			✓
E/E/PES Electrical Protective Devices	8.6.4.19.10	✓		

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1	✓		
Governors	8.6.4.20.2	✓		
Oil Buffers	8.6.4.20.3			✓
Braking System	8.6.4.20.4	✓		
Emergency and Standby Power Operation	8.6.4.20.5	✓		
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6	✓		
Power Opening of Doors	8.6.4.20.7	✓		
Leveling Zone & Leveling Speed	8.6.4.20.8	✓		
Inner Landing Zone	8.6.4.20.9			✓
Emergency Stopping Distance	8.6.4.20.10	✓		

**GOVERNOR & SAFETY TEST (Rule 1002.3A)**


Gov. Trip Spd	Prev.	Present	245	fpm	Gov. Pull Thru	150	
O.S. Trip Spd	Prev.	Present	210	fpm	Gov. Pull Out		
Weight Test	No Load	Full Load	✓		Capacity	3500	Length of Slide- Left 4" Right 4"
Was Load & Speed Test Satisfactory?	Yes	✓	No		Brake at 125%	Yes	✓ No
Safety Type	Instant.	Flex Guide	Other		Was Governor Sealed	Yes	✓ No
		✓			Was Governor Tagged	Yes	✓ No

**OIL BUFFER TEST (Rule 100.2A) Annual**

Load & Speed Test Satisfactory?	Yes	✓	No	Oil Level & Return Test Satisfactory?	Yes	✓	No
---------------------------------	-----	---	----	---------------------------------------	-----	---	----

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
# of Landings	2.27.3.2.1.(a)	✓		
Machine Room	2.27.3.2.1.(b)	✓		
Hoistway	2.27.3.2.1.(c)	✓		
Pit	2.27.3.2.1.(c)	✓		

Comments: FAID TEST COMPLETED - PASS

Signature of Inspector  QEI # IL06320	Signature of Person Conducting Test & State License # SEAN IL02845 KONE Employed by (Company Name)
Inspector's State of Illinois License #	



# PERIODIC TESTS OF ELECTRIC ELEVATORS

EMER. POWER TEST T40211



**EIS / Elevator Inspection Service**  
Phone 630.323.6541 • Fax 630.323.7149

Date 11 / 3 / 2023  
V - T - C WHEATON  
State of IL Reg. I.D.# T006915, 16 + 17  
Date of Last 5 Year Test 11 / 2 / 23  
P.O.# 4545848751  
Bldg. I.D. #1 #2 + #3 PASS  
 Pass  Freight / Service - Make: KONE  
Speed: 150 Capacity: 2500/3500

Bldg. Name: WHEATON PROPERTIES  
Address: 120 E. LIBERTY DR.  
Bldg. Phone:  
Owner / Manager Name

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			
Safeties	8.6.4.19.2			
Governors	8.6.4.19.3			
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			
Normal & Final Terminal Stopping Devices	8.6.4.19.5			
Firefighters' Emergency Operation	8.6.4.19.6			
Standby or Emergency Power Operation	8.6.4.19.7	✓		
Power Operation of Door System	8.6.4.19.8			
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			
E/E/PES Electrical Protective Devices	8.6.4.19.10			

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1			
Governors	8.6.4.20.2			
Oil Buffers	8.6.4.20.3			
Braking System	8.6.4.20.4			
Emergency and Standby Power Operation	8.6.4.20.5	✓		
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6			
Power Opening of Doors	8.6.4.20.7			
Leveling Zone & Leveling Speed	8.6.4.20.8			
Inner Landing Zone	8.6.4.20.9			
Emergency Stopping Distance	8.6.4.20.10			

### GOVERNOR & SAFETY TEST (Rule 1002.3A)

Gov. Trip Spd	Prev.	Present	fpm	Gov. Pull Thru		
O.S. Trip Spd	Prev.	Present	fpm	Gov. Pull Out		
Weight Test	No Load	Full Load	Capacity	Length of Slide-	Left	Right
Was Load & Speed Test Satisfactory?	Yes	No		Brake at 125%	Yes	No
Safety Type	Instant.	Flex Guide	Other	Was Governor Sealed	Yes	No
				Was Governor Tagged	Yes	No

### OIL BUFFER TEST (Rule 100.2A) Annual

Load & Speed Test Satisfactory?	Yes	No	Oil Level & Return Test Satisfactory?	Yes	No
---------------------------------	-----	----	---------------------------------------	-----	----

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
# of Landings	2.27.3.2.1.(a)			
Machine Room	2.27.3.2.1.(b)			
Hoistway	2.27.3.2.1.(c)			
Pit	2.27.3.2.1.(c)			

Comments: 2 HRS

Signature of Inspector [Signature] QEI # 1106320  
Inspector's State of Illinois License # 1106320

Signature of Person Conducting Test & State License # 1102845  
Employed by (Company Name) KONE