



DATE	02-01-2024
ST JOB NUMBER	32239760
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Southeastern Spine Institute 1625 Hospital Drive Mount Pleasant, SC 29464
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	1st floor by restroom nook	ABC	10 lb	Ansul	2035	2029	Yes	A	Good
2	3rd floor suite 360 exam 1 hall	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
3	3rd floor suite 360 exam 4 hall	ABC	5 lb	Buckeye	2034	2028	Yes	B	Good
4	3rd floor suite 370b checkout area	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
5	3rd floor suite 370b back exit	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
6	3rd floor suite 350 exam 5 hall	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
7	3rd floor suite 350 hall behind checkin	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
8	3rd floor suite 350 breakroom hall	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
9	Exam 12	ABC	5 lb	Buckeye	34	28	Yes	A	Good
10	3-floor hallway 350	ABC	10 lb	Amerex	31	25	Yes	A	Good
11	3-floor physical therapy under sink	ABC	2.5 lb	Kidde	34	27	Yes	B	Good
12	3-floor by lab	ABC	10 lb	Amerex	31	25	Yes	A	Good
13	3-floor hallway	ABC	10 lb	Amerex	31	25	Yes	A	Good
14	2-floor by men restroom waiting area	ABC	10 lb	Amerex	31	25	Yes	B	Good
15	Across e202	ABC	10 lb	Amerex	31	25	Yes	B	Good
16	2-floor exit stair	ABC	10 lb	Amerex	31	25	Yes	B	Good
17	2-floor break room	ABC	10 lb	Amerex	31	25	Yes	A	Good
18	2-floor w221	ABC	10 lb	Amerex	31	25	Yes	A	Good
19	2-floor back of check out	ABC	10 lb	Amerex	31	25	Yes	B	Good
20	1-floor mri 120	Water Mist	6 L	Amerex	29	0	Yes	B	Good hydrotest fixed
21	MRI w117	Water Mist	6 L	Amerex	29	0	Yes	B	Good
22	120 mri	ABC	10 lb	Amerex	31	25	Yes	B	Good
23	Hallway 1-floor mri	ABC	10 lb	Amerex	31	25	Yes	B	Good
24	B128-1. floor	ABC	10 lb	Amerex	31	25	Yes	B	Good
25	1-floor hallway exam 2	ABC	10 lb	Amerex	31	25	Yes	B	Good
26	Across from restricted areas	ABC	10 lb	Amerex	31	25	Yes	B	Good
27	By room 134	ABC	10 lb	Amerex	31	25	Yes	B	Good
28	Across room 179	ABC	10 lb	Amerex	31	25	Yes	A	Good
29	Room105	ABC	10 lb	Amerex	31	25	Yes	B	Good
30	E124	ABC	10 lb	Amerex	31	25	Yes	A	Good
31	E-118	ABC	10 lb	Amerex	31	25	Yes	B	Good



DATE	02-01-2024
ST JOB NUMBER	32239760
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Southeastern Spine Institute 1625 Hospital Drive Mount Pleasant, SC 29464
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
32	By room -8	ABC	10 lb	Amerex	31	25	Yes	B	Good
33	1-floor by restroom	ABC	10 lb	Amerex	31	24	Yes	B	Good
34	Surgery	ABC	10 lb	Amerex	31	25	Yes	B	Good
35	Surgery	ABC	10 lb	Amerex	31	25	Yes	B	Good
36	Surgery	ABC	10 lb	Amerex	31	25	Yes	B	Good