



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: Waveland Property Group Inc **Date:** 09/24/2024 02:45pm CDT
Property: Rivers Edge Plaza, 105 Jackson Avenue **Job Number:** 36787723
Address: 105 Jackson Avenue **Technician:** Jay Heppeler
City: Naperville
State: IL **Zip:** 60540

FIRE EXTINGUISHER INSPECTION REPORT

Service Information

Annual Inspection: ☐ Monthly Inspection: ☐ Quantity of Fire Extinguishers at location: 1
Service Call: ☒ Survey: ☐ Quantity of Extinguishers Needing Return Trip: 0

Extinguisher Annual Inspection

Quantity	Size	Type

Extinguishers Serviced During This Inspection

Quantity	Size	Type	Reason
1	10 lb.	ABC	NEW

Extinguishers To Be Serviced

Quantity	Size	Type	Reason

Miscellaneous

Quantity	Part	Notes

COMMENTS

Installed new 10lb abc in lobby to replace 5lb abc.
5lb abc was moved to FACP closet and can be used as a spare/backup

INSPECTION & SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED OWNER OR OWNER'S REPRESENTATIVE:
By this signature, I certify that the information on this form is correct at the time and place of my inspection, and that all equipment tested at this time was left in operational condition upon completion of this inspection except as noted in comments above.
☒ Service work completed during this inspection
☐ Service work not completed due to insufficient equipment available
☐ Service work declined by owner/representative
☐ Special order items needed to complete job

Agent not on site

OWNER / REPRESENTATIVE SIGNATURE

Taylor
PRINT NAME

9-24-24
DATE

INSPECTOR SIGNATURE

Jay Heppeler
PRINT NAME

3284-1
LICENSE #