



Fire Alarm and Life Safety System Inspection Certificate

204217-Rush Copley Healthplex
1900 W. Ogden Ave
Aurora, IL 60504

Tested to NFPA 72 Standards

This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date
Aug 20, 2024

Building: 204217-Rush Copley Healthplex
Contact: Warren Poi
Title: Contact

Company: Alarm Detection Systems, Inc.
Contact: Mario Ruiz-Aguado
Title: Inspector

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.com

Building Information		
Building: 204217-Rush Copley Healthplex	Contact: Warren Poi	
Address: 1900 W. Ogden Ave	Phone: (630) 375-2915	
Address:	Fax:	
City/State/ZIP Code: Aurora, IL 60504	Mobile:	
Country: United States of America	Email: warren.poi@rushcopley.com	
Inspection Performed By		
Company: Alarm Detection Systems, Inc.	Inspector: Mario Ruiz-Aguado	
Address: 1111 Church Rd.	Phone: 6308445312	
Address: Alarm License #127-000143	Fax:	
City/State/ZIP Code: Aurora, IL 60505	Mobile:	
Country: United States of America	Email: Mruiz@adsalarm.com	
System Control Unit		
Manufacturer: Edwards	Inspection Date: 08/20/2024	IDC Style:
Model Number: io1000	Install Date: 06/24/2020	SLC Style:
Software Version:	Version Date: 06/24/2020	NAC Style:
Location: Office 1st FI Electrical room	Current Protection: Breaker	
Monitoring		
Company: Alarm Detection Systems	Phone: 630-844-6302	Account #:
Central Station Signal Verification		
Type: Digital Radio	Mfg: AES	Model #: 7707
Test Time/Date: 8/20/24 7:29:31 AM	Restore Time:	Note:
Type of Signal	Signal Confirmation	Notes
Type: Supervisory	Confirmed Time: 1330	Note:
Type: Trouble	Confirmed Time: 1330	Note:
Type: Alarm	Confirmed Time: 1330	Note:

Inspection Summary								
Category:	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Control	21	18.75%	21	100.00%	21	100.00%	0	0.00%
Indicating	1	0.89%	1	100.00%	1	100.00%	0	0.00%
Initiating	81	72.32%	80	98.77%	70	87.50%	10	12.50%
Monitor	3	2.68%	3	100.00%	3	100.00%	0	0.00%
Supervisory	6	5.36%	6	100.00%	6	100.00%	0	0.00%
Totals	112	100%	111	99.11%	101	90.99%	10	9.01%

Certification	
Company: Alarm Detection Systems, Inc.	Building: 204217-Rush Copley Healthplex
Inspector: Mario Ruiz-Aguado	Contact: Warren Poi
	
Signed: Feb 27, 2024	Signed:

Mario Ruiz-Aguado Certifications	
Certification Type	Number
State of Illinois - PERC	129.234923

Discrepancy Report

Generated by: BuildingReports.com

Building: 204217-Rush Copley Healthplex Control Panel: 1 - Edwards io1000

The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.

Device Type	Manufacturer	ModelNumber	Date	Qty
Items listed for Recall or Replacement/Upgrade				

No items found during this inspection.

ScanID	Location	Problem	Address	Reference
--------	----------	---------	---------	-----------

Initiating

Pull Station

01110520	Healthplex Basement Boxing ring exit		1-200	
01110521	Healthplex Basement Boxing ring locker exit		1-200	
01110522	Healthplex Basement boys locker room		1-200	
01110556	Healthplex Basement family locker rm by exit to pool		1-200	
01110555	Healthplex Basement family locker room		1-200	
01110523	Healthplex Basement girls locker room		1-200	
63099958	Healthplex Basement pool south exit / Door #4		1-200	
01110557	Healthplex Basement stair by elevator		1-200	

Building: 204217-Rush Copley Healthplex Control Panel: 2

The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.

Device Type	Manufacturer	ModelNumber	Date	Qty
Items listed for Recall or Replacement/Upgrade				

No items found during this inspection.

ScanID	Location	Problem	Address	Reference
--------	----------	---------	---------	-----------

Initiating

Smoke Detector

88862352	Ground Lobby gym area	Failed to Report	2	NFPA72 14.2.2.2.2
88862353	Basement elevator mechanical room	Failed to Report	2	NFPA72 14.2.2.2.2

Code References

NFPA72 14.2.2.2.2 System deficiencies shall be corrected.

Code References

Proposed Solutions Report

Generated by: *BuildingReports.com*

Building: 204217-Rush Copley Healthplex **Control Panel: 1 - Edwards io1000**

The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.

ScanID	Location	Solution	Model #	Cost	Fix
Initiating					
Pull Station					
01110520	Healthplex Basement Boxing ring exit			T/M	<input type="checkbox"/>
01110521	Healthplex Basement Boxing ring locker exit			T/M	<input type="checkbox"/>
01110522	Healthplex Basement boys locker room			T/M	<input type="checkbox"/>
01110556	Healthplex Basement family locker rm by exit to pool			T/M	<input type="checkbox"/>
01110555	Healthplex Basement family locker room			T/M	<input type="checkbox"/>
01110523	Healthplex Basement girls locker room			T/M	<input type="checkbox"/>
63099958	Healthplex Basement pool south exit / Door #4			T/M	<input type="checkbox"/>
01110557	Healthplex Basement stair by elevator			T/M	<input type="checkbox"/>

Building: 204217-Rush Copley Healthplex **Control Panel: 2**

The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.

ScanID	Location	Solution	Model #	Cost	Fix
Initiating					
Smoke Detector					
88862352	Ground Lobby gym area		io1000	T/M	<input type="checkbox"/>
88862353	Basement elevator mechanical room		io1000	T/M	<input type="checkbox"/>
			PO #: (none)	T/M	

Inspection & Testing

Generated by: BuildingReports.com

Building: 204217-Rush Copley Healthplex	Control Panel: 1 - Edwards io1000
---	-----------------------------------

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Control				
Annunciator	Office 1st FI Main entrance	Annual	8:28:42 AM	08/20/2024
Battery	Basement Office Suite 106	Annual	7:48:29 AM	08/20/2024
Battery	Basement Office Suite 106	Annual	7:48:48 AM	08/20/2024
Battery	Healthplex 1st FI closet by basketball court	Annual	1:08:57 PM	08/20/2024
Battery	Healthplex 1st FI closet by basketball court	Annual	1:09:38 PM	08/20/2024
Battery	Office 1st FI FACP	Annual	7:32:33 AM	08/20/2024
Battery	Office 1st FI FACP	Annual	7:32:47 AM	08/20/2024
Battery	Office 1st FI Power supply	Annual	7:33:33 AM	08/20/2024
Battery	Office 1st FI Power supply	Annual	7:33:48 AM	08/20/2024
Battery	Office 1st FI Radio	Annual	7:35:27 AM	08/20/2024
Battery	Office 1st FI Suite 203/205	Annual	8:17:03 AM	08/20/2024
Battery	Office 1st FI Suite 203/205	Annual	8:17:16 AM	08/20/2024
Battery	Office 1st FI Suite 206 electrical room	Annual	7:17:01 AM	08/20/2024
Battery	Office 1st FI Suite 206 electrical room	Annual	7:17:16 AM	08/20/2024
Communicator	Office 1st FI Electrical room by FACP	Annual	7:29:31 AM	08/20/2024
Control Panel	Office 1st FI Electrical room	Annual	7:31:50 AM	08/20/2024
Power Supply	Basement Office Suite 106 hallway by electrical panels	Annual	7:48:16 AM	08/20/2024
Power Supply	Healthplex 1st FI closet by basketball court	Annual	1:08:45 PM	08/20/2024
Power Supply	Office 1st FI Electrical room	Annual	7:34:51 AM	08/20/2024
Power Supply	Office 1st FI Suite 203/205 storage	Annual	8:17:47 AM	08/20/2024
Power Supply	Office 1st FI Suite 206 electrical room	Annual	7:15:52 AM	08/20/2024
Indicating				
Horn/Strobe	44 A/Vs, 16 strobes Audio - Visuals	Annual	9:03:21 AM	08/20/2024
Initiating				
Duct Detector	Healthplex 1st FI Center pillar south basketball	Annual	9:41:46 AM	08/20/2024
Duct Detector	Healthplex 1st FI Northeast treadmill stage	Annual	9:37:45 AM	08/20/2024
Duct Detector	Healthplex 1st FI Northeast treadmill stage	Annual	9:38:00 AM	08/20/2024

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Duct Detector	Healthplex 1st FI basketball storage room right side of nac	Annual	1:08:03 PM	08/20/2024
Duct Detector	Healthplex 1st FI center pillar north by snack area	Annual	1:17:29 PM	08/20/2024
Duct Detector	Healthplex 1st FI center pillar north by snack area	Annual	1:17:41 PM	08/20/2024
Duct Detector	Healthplex Basement Sprunkler mechanical room	Annual	12:28:27 PM	08/20/2024
Duct Detector	Healthplex Basement sprinkler mechanical room	Annual	12:28:03 PM	08/20/2024
Heat Detector	Basement Office electrical room	Annual	8:33:11 AM	08/20/2024
Heat Detector	Healthplex 1st FI Office Kitchen	Annual	12:56:38 PM	08/20/2024
Heat Detector	Healthplex Basement Office mechanical room	Annual	8:33:24 AM	08/20/2024
Heat Detector	Healthplex Basement mens locker mechanical room	Annual	11:51:45 AM	08/20/2024
Heat Detector	Healthplex Basement pool east mech room	Annual	12:07:51 PM	08/20/2024
Pull Station	Basement Office hall by elevator	Annual	7:37:31 AM	08/20/2024
Pull Station	Basement Office hall by suite 110	Annual	7:40:13 AM	08/20/2024
Pull Station	Healthplex 1st FI Office Kitchen	Annual	12:56:09 PM	08/20/2024
Pull Station	Healthplex 1st FI Southeast entrance	Annual	9:16:37 AM	08/20/2024
Pull Station	Healthplex 1st FI main entrance	Annual	9:13:52 AM	08/20/2024
Pull Station	Healthplex 1st FI northwest in weight area	Annual	9:21:36 AM	08/20/2024
Pull Station	Healthplex 1st FI observation exit	Annual	9:18:14 AM	08/20/2024
Pull Station	Healthplex Basement Northeast stair	Annual	9:46:23 AM	08/20/2024
Pull Station	Healthplex Basement Pool northeast	Annual	12:42:18 PM	08/20/2024
Pull Station	Healthplex Basement Tennis court north center	Annual	11:34:35 AM	08/20/2024
Pull Station	Healthplex Basement Tennis courts west wall north	Annual	11:35:45 AM	08/20/2024
Pull Station	Healthplex Basement mens locker room	Annual	9:52:35 AM	08/20/2024
Pull Station	Healthplex Basement mens locker room exit	Annual	11:31:56 AM	08/20/2024
Pull Station	Healthplex Basement pool northwest /door #5	Annual	12:39:59 PM	08/20/2024
Pull Station	Healthplex Basement tennis east wall north	Annual	11:42:26 AM	08/20/2024
Pull Station	Healthplex Basement tennis south center	Annual	11:39:56 AM	08/20/2024
Pull Station	Healthplex Basement womens locker room	Annual	9:50:21 AM	08/20/2024
Pull Station	Healthplex Basement womens locker roomeast exit	Annual	1:02:49 PM	08/20/2024
Pull Station	Office 1st FI Hallway by FACP	Annual	6:53:06 AM	08/20/2024
Pull Station	Office 1st FI Hallway by suite 210	Annual	7:22:16 AM	08/20/2024

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Pull Station	Office 1st FI Main entrance	Annual	7:01:58 AM	08/20/2024
Remote Test Switch	Healthplex 1st FI Center pillar south basketball	Annual	12:52:24 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI Southwest basketball court	Annual	12:52:01 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI center pillar north by snack area	Annual	1:17:17 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI kids gym south east wall	Annual	12:49:04 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI kids gym southeast wall	Annual	12:48:48 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI kids gym southeast wall	Annual	12:49:16 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI southwest kids gym wall	Annual	12:50:54 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI studio 1 east wall	Annual	1:13:39 PM	08/20/2024
Remote Test Switch	Healthplex 1st FI studio 1 east wall	Annual	1:14:24 PM	08/20/2024
Remote Test Switch	Healthplex Basement mens locker mech room	Annual	11:50:50 AM	08/20/2024
Remote Test Switch	Office 1st FI Hall by FACP	Annual	6:55:30 AM	08/20/2024
Remote Test Switch	Office 1st FI Hallway by suite 203	Annual	6:55:36 AM	08/20/2024
Remote Test Switch	Office 1st FI Hallway by suite 210	Annual	7:25:18 AM	08/20/2024
Remote Test Switch	Office 1st FI Main entrance	Annual	7:02:40 AM	08/20/2024
Remote Test Switch	Office 1st FI hallway by suite 210	Annual	7:23:04 AM	08/20/2024
Smoke Detector	Basement Office Suite 102	Annual	7:59:13 AM	08/20/2024
Smoke Detector	Basement Office Suite 102 electrical room	Annual	7:55:26 AM	08/20/2024
Smoke Detector	Basement Office Suite 104	Annual	7:53:20 AM	08/20/2024
Smoke Detector	Basement Office Suite 108 electrical room	Annual	7:46:35 AM	08/20/2024
Smoke Detector	Basement Office mechanical room	Annual	8:33:05 AM	08/20/2024
Smoke Detector	Basement Office suite 100	Annual	8:06:51 AM	08/20/2024
Smoke Detector	Basement Office suite 100	Annual	8:36:26 AM	08/20/2024
Smoke Detector	Healthplex Basement Sprinkler mechanical room	Annual	12:30:20 PM	08/20/2024
Smoke Detector	Office 1st FI Above FACP	Annual	7:31:59 AM	08/20/2024
Smoke Detector	Office 1st FI Main entrance above annunciator	Annual	7:06:51 AM	08/20/2024
Smoke Detector	Office 1st FI Outside FACP room	Annual	6:51:45 AM	08/20/2024
Smoke Detector	Office 1st FI Outside FACP room	Annual	6:52:08 AM	08/20/2024
Smoke Detector	Office 1st FI Suite 203/205 above power supply	Annual	8:18:12 AM	08/20/2024
Smoke Detector	Office 1st FI Suite 206 electrical room	Annual	7:15:15 AM	08/20/2024
Smoke Detector	Office 1st FI suite 206 electrical room	Annual	8:28:34 AM	08/20/2024
Smoke Detector	Office 1st FI Closet storage electrical Room	Annual	6:59:25 AM	08/20/2024

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Smoke Detector	Office 1st FI Closet storage electrical Room Suite 202	Annual	7:08:38 AM	08/20/2024
Waterflow Switch	Healthplex Basement mechanical room	Annual	12:21:10 PM	08/20/2024
Waterflow Switch	Healthplex Basement mechanical room	Annual	12:23:20 PM	08/20/2024
Waterflow Switch	Healthplex Basement mechanical room	Annual	12:23:33 PM	08/20/2024
Waterflow Switch	Healthplex Basement mechanical room	Annual	12:24:58 PM	08/20/2024
Monitor				
Monitoring	Alarm	Annual	1:26:44 PM	08/20/2024
Monitoring	Supervisory	Annual	1:26:23 PM	08/20/2024
Monitoring	Trouble	Annual	1:26:41 PM	08/20/2024
Supervisory				
Tamper Switch	Healthplex Basement mechanical room	Annual	12:10:01 PM	08/20/2024
Tamper Switch	Healthplex Basement mechanical room	Annual	12:10:05 PM	08/20/2024
Tamper Switch	Healthplex Basement mechanical room	Annual	12:10:12 PM	08/20/2024
Tamper Switch	Healthplex Basement mechanical room	Annual	12:10:17 PM	08/20/2024
Tamper Switch	Healthplex Basement mechanical room	Annual	12:10:23 PM	08/20/2024
Tamper Switch	Healthplex Basement mechanical room	Annual	12:10:29 PM	08/20/2024
Device Type	Location	Service	Time	Date
<i>Failed/Other</i>				
Initiating				
Pull Station	Healthplex Basement Boxing ring exit	Annual	12:00:15 PM	08/20/2024
Pull Station	Healthplex Basement Boxing ring locker exit	Annual	12:00:12 PM	08/20/2024
Pull Station	Healthplex Basement boys locker room	Annual	12:00:10 PM	08/20/2024
Pull Station	Healthplex Basement family locker rm by exit to pool	Annual	12:00:01 PM	08/20/2024
Pull Station	Healthplex Basement family locker room	Annual	12:00:05 PM	08/20/2024
Pull Station	Healthplex Basement girls locker room	Annual	12:00:08 PM	08/20/2024
Pull Station	Healthplex Basement pool south exit / Door #4	Annual	11:59:57 AM	08/20/2024
Pull Station	Healthplex Basement stair by elevator	Annual	11:59:52 AM	08/20/2024
Device Type	Location	Service	Time	Date
<i>Untested</i>				
Initiating				
Smoke Detector	Basement Healthplex northwest mech room pool			

Building: 204217-Rush Copley Healthplex Control Panel: 2

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Failed/Other</i>				
Initiating				
Smoke Detector	Ground Lobby gym area	Annual	11:47:34 AM	02/27/2024
Smoke Detector	Basement elevator mechanical room	Annual	11:59:50 AM	02/27/2024

Service Summary

Generated by: *BuildingReports.com*

Building: 204217-Rush Copley Healthplex		
<i>The Service Summary section provides an overview of the services performed in this report.</i>		
Device Type	Service	Quantity
<i>Failed/Other</i>		
Pull Station	Annual	8
Smoke Detector	Annual	2
Total		10
<i>Passed</i>		
Annunciator	Annual	1
Battery	Annual	13
Communicator	Annual	1
Control Panel	Annual	1
Duct Detector	Annual	8
Heat Detector	Annual	5
Horn/Strobe	Annual	1
Monitoring	Annual	3
Power Supply	Annual	5
Pull Station	Annual	21
Remote Test Switch	Annual	15
Smoke Detector	Annual	17
Tamper Switch	Annual	6
Waterflow Switch	Annual	4
Total		101
<i>Untested</i>		
Smoke Detector		1
Total		1
Grand Total		112

Time, Temperature & Level Testing

Generated by: *BuildingReports.com*

Building: 204217-Rush Copley Healthplex			Control Panel: 1 - Edwards io1000			
<p><i>The Time, Temperature, & Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.</i></p>						
Type	Location	Comment	Sec	Deg	Lvl	ScanID
<i>Passed</i>						
Waterflow Switch						
	Healthplex Basement mechanical room	Passed	67	n/a	n/a	60822551
	Healthplex Basement mechanical room	Passed	65	n/a	n/a	60822549
	Healthplex Basement mechanical room	Passed	57	n/a	n/a	60822547
	Healthplex Basement mechanical room	Passed	46	n/a	n/a	60822545

Battery & Power Supply Testing

Generated by: *BuildingReports.com*

Building: 204217-Rush Copley Healthplex		Control Panel: 1 - Edwards io1000					
<p><i>The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i></p>							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
<i>Passed</i>							
Sealed Lead Acid	Basement Office Suite 106	7	12	13.5	13.5		
Sealed Lead Acid	Basement Office Suite 106	7	12	13.6	13.6		
Sealed Lead Acid	Healthplex 1st FI closet by basketball court	7Ah	12V	13.6	13.6		
Sealed Lead Acid	Healthplex 1st FI closet by basketball court	7Ah	12V	13.5	13.5		
Sealed Lead Acid	Office 1st FI FACP	12Ah	12V	12.9	12.9		
Sealed Lead Acid	Office 1st FI FACP	12Ah	12V	13.3	13.3		
Sealed Lead Acid	Office 1st FI Power supply	7Ah	12V	13.6	13.6		
Sealed Lead Acid	Office 1st FI Power supply	7Ah	12V	13.6	13.6		
Sealed Lead Acid	Office 1st FI Radio	7Ah	12V	13.7	13.7		
Sealed Lead Acid	Office 1st FI Suite 203/205	7Ah	12V	13.6	13.6		
Sealed Lead Acid	Office 1st FI Suite 203/205	7Ah	12V	13.6	13.6		
Sealed Lead Acid	Office 1st FI Suite 206 electrical room	7Ah	12V	13.2	13.2		
Sealed Lead Acid	Office 1st FI Suite 206 electrical room	7Ah	12V	13.2	13.2		

Inventory Report

Generated by: *BuildingReports.com*

Building: 204217-Rush Copley Healthplex

The Inventory Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided.

Device or Item	Category	% of Inventory	Quantity
Annunciator	Control	0.89%	1
Battery	Control	11.61%	13
Communicator	Control	0.89%	1
Control Panel	Control	0.89%	1
Duct Detector	Initiating	7.14%	8
Heat Detector	Initiating	4.46%	5
Horn/Strobe	Indicating	0.89%	1
Monitoring	Monitor	2.68%	3
Power Supply	Control	4.46%	5
Pull Station	Initiating	25.89%	29
Remote Test Switch	Initiating	13.39%	15
Smoke Detector	Initiating	17.86%	20
Tamper Switch	Supervisory	5.36%	6
Waterflow Switch	Initiating	3.57%	4

Zone Address Report

Generated by: *BuildingReports.com*

Building: 204217-Rush Copley Healthplex Control Panel: 1 - Edwards io1000

The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.

Address	Device Type	Location	Type	ScanID
Zone/Circuit: 128				
	Pull Station	Office 1st FI Hallway by FACP		01372021
Zone/Circuit: 138				
	Pull Station	Healthplex Basement womens locker room		01110528
Zone/Circuit: 173				
	Heat Detector	Healthplex Basement Office mechanical room	Rate-of-Rise	63099968
	Smoke Detector	Healthplex Basement Sprinkler mechanical room		63099967
001	Smoke Detector	Office 1st FI Above FACP		63119913
126	Pull Station	Healthplex Basement tennis south center		01110560
128	Heat Detector	Healthplex 1st FI Office Kitchen	Rate-of-Rise	01110503
128	Pull Station	Healthplex 1st FI Office Kitchen		01110502
128	Pull Station	Healthplex 1st FI main entrance		63099965
128	Pull Station	Office 1st FI Hallway by suite 210		01357646
128	Pull Station	Office 1st FI Main entrance		01357640
128	Smoke Detector	Office 1st FI Main entrance above annunciator		01110526
128	Smoke Detector	Office 1st FI Outside FACP room		01372019
128	Smoke Detector	Office 1st FI Outside FACP room		01372020
128	Smoke Detector	Office 1st FI Suite 203/205 above power supply		63099971
130	Remote Test Switch	Office 1st FI Main entrance		01357641
131	Remote Test Switch	Office 1st FI Hallway by suite 203		01357642
132	Remote Test Switch	Healthplex 1st FI center pillar north by snack area		01110509
133	Duct Detector	Healthplex 1st FI center pillar north by snack area		01110510
134	Duct Detector	Healthplex 1st FI center pillar north by snack area		01110511
135	Remote Test Switch	Healthplex 1st FI kids gym southeast wall		01110515
138	Pull Station	Healthplex Basement mens locker room		01110529
138	Pull Station	Healthplex Basement mens locker room exit		01110530
138	Pull Station	Healthplex Basement womens locker roomeast exit		01110554



Address	Device Type	Location	Type	ScanID
139	Remote Test Switch	Office 1st Fl hallway by suite 210		01357645
140	Duct Detector	Healthplex 1st Fl Northeast treadmill stage		01110507
141	Duct Detector	Healthplex 1st Fl Northeast treadmill stage		01110508
142	Remote Test Switch	Healthplex 1st Fl studio 1 east wall		01110506
143	Remote Test Switch	Healthplex 1st Fl studio 1 east wall		01110505
144	Remote Test Switch	Healthplex 1st Fl Southwest basketball court		01110514
146	Smoke Detector	Basement Office Suite 108 electrical room		01357656
147	Duct Detector	Healthplex 1st Fl Center pillar south basketball		01110512
148	Remote Test Switch	Healthplex 1st Fl Center pillar south basketball		01110513
149	Remote Test Switch	Healthplex 1st Fl southwest kids gym wall		63099959
150	Remote Test Switch	Healthplex 1st Fl kids gym south east wall		01110516
151	Duct Detector	Healthplex 1st Fl basketball storage room right side of nac		01110518
152	Remote Test Switch	Healthplex 1st Fl kids gym southeast wall		01110517
153	Remote Test Switch	Office 1st Fl Hallway by suite 210		01357644
154	Remote Test Switch	Office 1st Fl Hall by FACP		01357643
155	Tamper Switch	Healthplex Basement mechanical room		01110546
155	Tamper Switch	Healthplex Basement mechanical room		01110547
156	Duct Detector	Healthplex Basement Sprunkler mechanical room		01110536
156	Duct Detector	Healthplex Basement sprinkler mechanical room		01110537
157	Pull Station	Healthplex Basement Tennis court north center		01110558
157	Pull Station	Healthplex Basement Tennis courts west wall north		01110559
157	Pull Station	Healthplex Basement tennis east wall north		01110561
158	Tamper Switch	Healthplex Basement mechanical room		01110543
159	Waterflow Switch	Healthplex Basement mechanical room		60822547
160	Tamper Switch	Healthplex Basement mechanical room		01110542
161	Waterflow Switch	Healthplex Basement mechanical room		60822545
164	Heat Detector	Healthplex Basement mens locker mechanical room		63099956
165	Heat Detector	Healthplex Basement pool east mech room		63099957
166	Pull Station	Healthplex 1st Fl northwest in weight area		01110504
167	Pull Station	Healthplex 1st Fl Southeast entrance		01110524
167	Pull Station	Healthplex 1st Fl observation exit		01110525
168	Tamper Switch	Healthplex Basement mechanical room		60822553
169	Waterflow Switch	Healthplex Basement mechanical room		60822551
170	Tamper Switch	Healthplex Basement mechanical room		01110544
171	Waterflow Switch	Healthplex Basement mechanical room		60822549

Address	Device Type	Location	Type	ScanID
172	Heat Detector	Basement Office electrical room	Rate-of-Rise	01110550
190	Pull Station	Basement Office hall by elevator		01372023
190	Pull Station	Basement Office hall by suite 110		01372022
190	Smoke Detector	Basement Office mechanical room		63099800
190	Pull Station	Healthplex Basement Northeast stair		01110527
190	Pull Station	Healthplex Basement Pool northeast		01110534
190	Pull Station	Healthplex Basement pool northwest /door #5		01110535
190	Smoke Detector	Basement Healthplex northwest mech room pool		63099963
200	Pull Station	Healthplex Basement Boxing ring exit		01110520
200	Pull Station	Healthplex Basement Boxing ring locker exit		01110521
200	Pull Station	Healthplex Basement boys locker room		01110522
200	Pull Station	Healthplex Basement family locker rm by exit to pool		01110556
200	Pull Station	Healthplex Basement family locker room		01110555
200	Pull Station	Healthplex Basement girls locker room		01110523
200	Pull Station	Healthplex Basement pool south exit / Door #4		63099958
200	Pull Station	Healthplex Basement stair by elevator		01110557
201	Remote Test Switch	Healthplex Basement mens locker mech room		01110531
207	Smoke Detector	Office 1st Fl Suite 206 electrical room		01357650
209	Smoke Detector	Basement Office Suite 102		01357648
209	Smoke Detector	Basement Office Suite 102 electrical room		01357655
209	Smoke Detector	Basement Office suite 100		85636989
209	Smoke Detector	Basement Office suite 100		85636990