

Report of Inspection / Test

Annual NFPA 10



06-24-2025

Conducted by: Shop Guy

Property

Shambaugh-369 Roosevelt Rd
369 Roosevelt Rd
Glen Ellyn IL 60137

U.S. Fire & Safety Equipment Co.
0064-AB
2412 Millennium Dr
Elgin IL 60124
7737634422 x201
ppaschall@usfsco.com

Portable Fire Extinguisher Summary

Type	Tested	Pass	Fail	Not Tested	Total
ABC	4	4	0	0	4

Portable Fire Extinguishers Inspection List - F45 TRAINING

ID#	Make	Model	Location	Desc	Type	Size	Year of Mfr.	5 Year	6 Year	12 Year	Status	Notes
	Badger		Front entrance	Fork	ABC	5#	2023	N/A	2041	2035	Pass	
	Badger		Back exit	Fork	ABC	5#	2018	N/A	2036	2030	Pass	

Portable Fire Extinguishers Inspection List - MATTRESS FIRM

ID#	Make	Model	Location	Desc	Type	Size	Year of Mfr.	5 Year	6 Year	12 Year	Status	Notes
	Ansul		Front entrance	Fork	ABC	5#	2005	N/A	2031	2037	Pass	
	Ansul		Back exit	Fork	ABC	5#	2012	N/A	2031	2037	Pass	