



7214 Peppermill Parkway
North Charleston, SC 29418

DATE	01-27-2026
ST JOB NUMBER	45766555
TECHNICIAN	Karim Porter
CUSTOMER LOCATION	Hospital Development Mt Pleasant/Medical Properties, LLC 1625 Hospital Drive Mount Pleasant, SC, 29464
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment / Deficiencies
1	1st fl lobby near restroom	ABC	10 lb	Ansul	2035	2029	Yes	B	Good
2	1st fl suite 100 entry hall near stairwell/ W117	ABC	10 lb	Badger	2031	2037	Yes	B	Good
3	1st fl suite 100 Inside MRI ZONE III	Water Mist	2.5 gal	Amerex	2024	0		B	Due hydro Due hydro
4	1st fl suite 100 inside MRI ZONE III wall near electrical room 102	Water Mist	2.5 gal	Amerex	2029	0	Yes	B	Good
5	1st fl suite 110 hall near room E124	ABC	10 lb	Badger	2031	2037	Yes	B	Good
6	1st fl suite 110 back hall near side exit/ breakroom	ABC	10 lb	Badger	2031	2037	Yes	B	Good
7	1st fl suite 110 near recovery room 8/ exit	ABC	10 lb	Badger	2031	2037	Yes	B	Good
8	1st fl suite 110 elevator room 105 near exit	ABC	10 lb	Ansul	2035	2029	Yes	B	Good
9	1st fl suite 110 hall near radiation room E179	ABC	10 lb	Badger	2031	2037	Yes	B	Good
10	1st fl suite 110 ORs near room E128	ABC	10 lb	Badger	2031	2037	Yes	B	Good
11	1st fl suite 110 ORs across from room E183	ABC	10 lb	Badger	2031	2037	Yes	B	Good
12	1st fl suite 110 ORs near room E134	ABC	10 lb	Badger	2031	2037	Yes	B	Good
13	2nd fl right side waiting area near restroom/water fountain	ABC	10 lb	Amerex	2031	2037	Yes	B	Good
14	2nd fl back hall near stairwell	ABC	10 lb	Amerex	2031	2037	Yes	B	Good
15	2nd fl center waiting area near checkout desk	ABC	10 lb	Amerex	2031	2037	Yes	B	Good
16	2nd fl nurses station near stairwell/ room W221	ABC	10 lb	Amerex	2031	2037	Yes	B	Good
17	2nd fl center hall across from room E202A	ABC	10 lb	Badger	2031	2037	Yes	B	Good
18	2nd fl inside breakroom	ABC	10 lb	Amerex	2031	2037	Yes	B	Good
19	3rd fl 370B entry hall	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
20	3rd fl 370B hall back emergency exit	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
21	3rd fl E310 under sink	ABC	2.5 lb	Other	2033	2027	Yes	A	Good
22	3rd fl hall end near stairwell/ E340 corner	ABC	10 lb	Amerex	2032	2038	Yes	B	Good
23	3rd fl hall 350	ABC	10 lb	Amerex	2031	2037	Yes	B	Good



7214 Peppermill Parkway
North Charleston, SC 29418

DATE	01-27-2026
ST JOB NUMBER	45766555
TECHNICIAN	Karim Porter
CUSTOMER LOCATION	Hospital Development Mt Pleasant/Medical Properties, LLC 1625 Hospital Drive Mount Pleasant, SC, 29464
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment / Deficiencies
24	3rd fl inside 350 hall near exam room 4	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
25	3rd fl inside 350 hall near breakroom/ conference room	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
26	3rd fl inside 350 hall near checkout desk	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
27	3rd fl inde 350 hall near exam room 12	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
28	3rd fl inside 360 hall near exam room 1	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good
29	3rd fl inside 360 hall near exam room 4	ABC	5 lb	Buckeye	2034	2028	Yes	A	Good