

PERIODIC TESTS OF ELECTRIC ELEVATORS

T 43240

2025/26 VR. ANNUAL INSPECTION REPORT



#1 PASSENGER CAR - NORTH

Elevator Inspection Service
Phone 630.323.6541 • Fax 630.323.7149

Bldg. Name: WHEATON PROPERTY
Address: 120 E LIBERTY
Bldg. Phone:
Owner / Manager Name

Date: 12/5/25
V-T-C: WHEATON
State of IL Reg. I.D.#: 1006916
Date of Last 5 Year Test: 11/1/23
P.O.#: 4555219769
Bldg. I.D.: PASS ONE
Pass / Freight / Service - Make: KONE
Speed: 150 Capacity: 2500

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			X
Safeties	8.6.4.19.2	X		
Governors	8.6.4.19.3	X		
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			X
Normal & Final Terminal Stopping Devices	8.6.4.19.5	X		
Firefighters' Emergency Operation	8.6.4.19.6	X		
Standby or Emergency Power Operation	8.6.4.19.7	X		
Power Operation of Door System	8.6.4.19.8	X		
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			X
E/E/PES Electrical Protective Devices	8.6.4.19.10	X		

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1			
Governors	8.6.4.20.2			
Oil Buffers	8.6.4.20.3			
Braking System	8.6.4.20.4			
Emergency and Standby Power Operation	8.6.4.20.5			
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6			
Power Opening of Doors	8.6.4.20.7			
Leveling Zone & Leveling Speed	8.6.4.20.8			
Inner Landing Zone	8.6.4.20.9			
Emergency Stopping Distance	8.6.4.20.10			

GOVERNOR & SAFETY TEST (Rule 1002.3A)

Gov. Trip Spd Prev. Present fpm	Gov. Pull Thru	
O.S. Trip Spd Prev. Present fpm	Gov. Pull Out	
Weight Test: No Load <input checked="" type="checkbox"/> Full Load <input type="checkbox"/>	Capacity: 2500	Length of Slide: Left Right
Was Load & Speed Test Satisfactory? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Brake at 125% Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Safety Type: Instant. Flex Guide <input checked="" type="checkbox"/> Other	Was Governor Sealed Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
	Was Governor Tagged Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	

OIL BUFFER TEST (Rule 100.2A) Annual

Load & Speed Test Satisfactory? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Oil Level & Return Test Satisfactory? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
---	---

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
COMPLETED # of Landings	2.27.3.2.1.(a)			
Total Hours Testing Machine Room	2.27.3.2.1.(b)			
Hoistway	2.27.3.2.1.(c)			
Pit	2.27.3.2.1.(c)			

Comments: 4-23
Signature of Inspector: [Signature] OEI # 05786

Signature of Person Conducting Test & State License #: SHAWN # 02845 KONE

Inspector's State of Illinois License # _____ Employed by (Company Name) _____

2025/26 YR. ANNUAL INSPECTION REPORT

ELEVATOR INSPECTION FORM

I 29893
7-23-25



745 McClintock Drive, Suite 235, Burr Ridge, IL 60527 • Phone 630-323-6541 / Fax 630-323-7149

Address: 120 E Liberty Dr Unit: #1 Pass
 Bldg. Name: Wheaton Properties Make: Kone
 Bldg. Rep.: _____ Speed: 150 fpm
 Phone No.: _____

Date: _____
 Code Edition: ASME A 17.1 _____ A17.3 _____
 V/T/C: Wheaton
 ID #: #1 Pass Convey # T006916
 Inspection & Test: Routine Periodic Acceptance
 Power: _____ FL/PT 12-25
 Capacity: Traction Em Ph XOK
 2500 Em Light XOK

TESTING DUE 12/25

	OK	NG	NA		OK	NG	NA	
1. ELEVATOR-INSIDE OF CAR								
1.1 Door reopening device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.24 (T) AC drives from a DC source	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.25 (T) Car, overhead, & deflector sheaves
1.2 Stop switches	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.25 (T) Traction sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.26 (T) Broken rope, chain, or tape switch
1.3 Operating control devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.26 (T) Secondary & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.27 Crosshead data plate & rope data tags
1.4 Sills & car floor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.27 (T) Rope fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.28 Counterweight & counterweight buffer
1.5 Car lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.28 (T) Terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.29 Counterweight safeties
1.6 Car emergency signal-lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.29 (T) Car & counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.30 Speed test
1.7 Car door or gate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.30 Hydraulic power unit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.31 Slack rope device-roped hydr clevs (*)
1.8 Door closing force	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.31 Relief valves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.32 Traveling sheave-roped hydr clevs (*)
1.9 Power closing of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.32 Control valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.33 (T) Compensating ropes & chains
1.10 Power opening of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.33 Tanks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1.11 Car vision panels & glass car doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.34 Flexible hydr hose & fitting assemblies	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4. ELEVATOR-OUTSIDE HOISTWAY
1.12 Car enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.35 Supply line & shutoff valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.1 Car platform guard
1.13 Emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.36 Hydraulic cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.2 Hoistway doors
1.14 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.37 Pressure switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.3 Vision panels
1.15 Signs & operating device symbols	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.38 Robed water hydraulic elevators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.4 Hoistway door locking devices
1.16 Rated load, platform area, & data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.39 Low oil protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.5 Access to hoistway
1.17 Standby power operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.40 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.6 Power closing of hoistway doors
1.18 Restricted opening of car or hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.41 Maintenance records	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.7 Sequence operation
1.19 Car Ride	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.42 Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.8 Hoistway enclosure
				3. ELEVATOR-TOP OF CAR				4.9 Elevator Parking devices
2. ELEVATOR-MACHINE ROOM				3.1 Top-of-car stop switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.10 Emergency doors in blind hoistways
2.1 Access to machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.2 Car top light & outlet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.11 (T) Separate counterweight hoistway
2.2 Headroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.3 Top-of-car operating device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.12 Standby power selection switch
2.3 Lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.13 Inspection control
2.4 Machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.5 Clearance, refuge, space standard railing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5. ELEVATOR-PIT
2.5 Housekeeping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.6 Final & emerg terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.1 Pit access, lighting, stop switch, & condition
2.6 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.7 Car leveling & anticreep devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.2 Bottom clearance, runby & min. refuge space
2.7 Fire extinguisher	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.8 Top emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.3 (T) Final & emergency terminal stopping devices
2.8 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.9 Floor & emerg identification numbering	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.4 Normal terminal stopping devices
2.9 Guarding of exposed auxiliary equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.10 Hoistway construction	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.5 Traveling cables
2.10 #ing of elevators, machines, disconnects	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.11 Hoistway smoke control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.6 Governor-rope tension devices
2.11 Disconnecting means & control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.12 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.7 Car Frame & platform
2.12 Controller wiring, fuses, grounding, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.13 Windows, projections, recesses, & setbacks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.8 Car safeties & guiding memb-incl roped-hydr elev(*)
2.13 Governor, overspeed switch, & seal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.14 Hoistway clearances	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.9 (T) Buffers & emerg terminal speed limiting devices
2.14 Code data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.15 Multiple hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.10 (T) Compensating chains, ropes & sheaves
2.15 (T) Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.16 Traveling cables & junction boxes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.11 Plunger & cylinder
2.16 (T) Overhead beam & fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.17 Door & gate equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.12 Car Buffer
2.17 (T) Drive machine brake	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.18 Car frame & stiles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.13 Guiding members
2.18 (T) Traction drive machines	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.19 Guide rails fastening & equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.14 Supply piping
2.19 (T) Gears, bearings, & flexible coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.20 Governor rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6. ELEVATOR FIRE SERVICE
2.20 (T) Winding drum mach & slack cable dev	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.21 Governor releasing carrier	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6.1 PH 1 ONLY
2.21 (T) Belt or chain-drive machine	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.22 Wire rope fastening & hitch plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6.2 PH 1 & PH 2
2.22 (T) Motor generator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.23 Suspension rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F.A.I.D. Date <u>11-12-23</u>
2.23 (T) Absorption of regenerated power	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.24 (T) Top counterweight clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7. ELEVATOR FACILITY IDENTIFICATION
								(410 ILCS 30/1)

COMMENTS: OK -- meets requirement NG -- insert number to identify comment NA -- not applicable (T) Traction Cars (*) Installed under A17 1b-1989 and later editions

THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY.
 THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.

FAIL - RE-INSPECT IN _____ DAYS
 PASS - CONDITION GOOD -
 Approved for Certificate

Elevator Co./Building Representative _____
 Elev Co Lic # IL _____
 Elev Mech Lic # IL _____

Inspector's Signature _____
 Inspector QEI # C5084
 Inspector's Lic # IL 05186

2025/26 YR. ANNUAL INSPECTION REPORT
PERIODIC TESTS OF ELECTRIC ELEVATORS
#2 PASSENGER CAR - SOUTH

T 44842

 EIS / Elevator Inspection Service Phone 630.323.6541 • Fax 630.323.7149	Date	12, 5, 25
	V - T - C	WHEATON
Bldg. Name: WHEATON PROPERTY Address: 120 E LIBERTY Bldg. Phone: Owner / Manager Name	State of IL Reg. I.D.#	1006915
	Date of Last 5 Year Test	11, 12, 3
	P.O.#	455521 9769
	Bldg. I.D.	PASS 120
	Pass / Freight / Service - Make:	KONE
	Speed:	150 Capacity: 2500

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			X
Safeties	8.6.4.19.2	X		
Governors	8.6.4.19.3	X		
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			X
Normal & Final Terminal Stopping Devices	8.6.4.19.5	X		
Firefighters' Emergency Operation	8.6.4.19.6	X		
Standby or Emergency Power Operation	8.6.4.19.7	X		
Power Operation of Door System	8.6.4.19.8	X		
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			X
E/E/PES Electrical Protective Devices	8.6.4.19.10	X		

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1			
Governors	8.6.4.20.2			
Oil Buffers	8.6.4.20.3			
Braking System	8.6.4.20.4			
Emergency and Standby Power Operation	8.6.4.20.5			
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6			
Power Opening of Doors	8.6.4.20.7			
Leveling Zone & Leveling Speed	8.6.4.20.8			
Inner Landing Zone	8.6.4.20.9			
Emergency Stopping Distance	8.6.4.20.10			

GOVERNOR & SAFETY TEST (Rule 1002.3A)							
Gov. Trip Spd	Prev.	Present	fpm	Gov. Pull Thru			
O.S. Trip Spd	Prev.	Present	fpm	Gov. Pull Out			
Weight Test	No Load	Full Load	Capacity	Length of Slide- Left	Right		
Was Load & Speed Test Satisfactory?	Yes	NA	No	Brake at 125%	Yes	No	X
Safety Type	Instant.	Flex Guide	Other	Was Governor Sealed	Yes	No	
				Was Governor Tagged	Yes	No	

OIL BUFFER TEST (Rule 100.2A) Annual			
Load & Speed Test Satisfactory?	Yes	NA	No
Oil Level & Return Test Satisfactory?	Yes	X	No

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
COMPLETED	# of Landings			
Total Hours Testing	Machine Room			
	Hoistway			
	Pit			

Comments:	
Signature of Inspector	Signature of Person Conducting Test & State License #
Inspector's State of Illinois License #	Employed by (Company Name)

Signature of Inspector: *Anthony Perez* OEI # 05186
 Signature of Person Conducting Test & State License #: SHAWN # 02845
 Employed by (Company Name): KONE

2025/26 YR. ANNUAL INSPECTION REPORT

ELEVATOR INSPECTION FORM

I 29894

7-23-25



#2 PASSENGER CAR SOUTH

Elevator Inspection Service

Est. 1976



745 McClintock Drive, Suite 235, Burr Ridge, IL 60527 • Phone 630-323-6541 / Fax 630-323-7149

Date _____
 Code Edition: ASME A17.1 _____ A17.3 _____
 VIT/C Wheaton
 ID # #2 Pass Convey # T006915
 Inspection & Test Routine Periodic Acceptance
 Power _____ FL/PT 12-24
 Capacity Traction Em Ph 05
 " 2500 Em Light OK

Address 120 E Liberty Dr Unit #2 Pass
 Bldg. Name Wheaton Properties Make Kone
 Bldg. Rep. _____ Speed 150 fpm
 Phone No. _____

	OK	NG	NA		OK	NG	NA		OK	NG	NA
1. ELEVATOR-INSIDE OF CAR											
1.1 Door reopening device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.24 (T) AC drives from a DC source	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.25 (T) Car, overhead, & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.2 Stop switches	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.25 (T) Traction sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.26 (T) Broken rope, chain, or tape switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.3 Operating control devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.26 (T) Secondary & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.27 Crosshead data plate & rope data tags	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.4 Sills & car floor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.27 (T) Rope fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.28 Counterweight & counterweight buffer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.5 Car lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.28 (T) Terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.29 Counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.6 Car emergency signal-lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.29 (T) Car & counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.30 Speed test	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.7 Car door or gate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.30 Hydraulic power unit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.31 Slack rope device-roped hydr elevs (*)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.8 Door closing force	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.31 Relief valves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.32 Traveling sheave-roped hydr elevs (*)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.9 Power closing of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.32 Control valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.33 (T) Compensating ropes & chains	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.10 Power opening of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.33 Tanks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4. ELEVATOR-OUTSIDE HOISTWAY			
1.11 Car vision panels & glass car doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.34 Flexible hydr hose & fitting assemblies	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.1 Car platform guard	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.12 Car enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.35 Supply line & shutoff valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.2 Hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.13 Emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.36 Hydraulic cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.3 Vision panels	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.14 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.37 Pressure switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.4 Hoistway door locking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.15 Signs & operating device symbols	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.38 Robed water hydraulic elevators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.5 Access to hoistway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.16 Rated load, platform area, & data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.39 Low oil protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.6 Power closing of hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.17 Standby power operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.40 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.7 Sequence operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.18 Restricted opening of car or hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.41 Maintenance records	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.8 Hoistway enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.19 Car Ride	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2.42 Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.9 Elevator Parking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. ELEVATOR-MACHINE ROOM											
2.1 Access to machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3. ELEVATOR-TOP OF CAR				4.10 Emergency doors in blind hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.2 Headroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.1 Top-of-car stop switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.11 (T) Separate counterweight hoistway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.3 Lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.2 Car top light & outlet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.12 Standby power selection switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.4 Machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.3 Top-of-car operating device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.13 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.5 Housekeeping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5. ELEVATOR-PIT			
2.6 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.5 Clearance, refuge space standard railing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.1 Pit access, lighting, stop switch, & condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.7 Fire extinguisher	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.6 Final & emerg terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.2 Bottom clearance, runby & min. refuge space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.8 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.7 Car leveling & anticreep devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.3 (T) Final & emergency terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.9 Guarding of exposed auxiliary equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.8 Top emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.10 #ing of elevators, machines, disconnects	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.9 Floor & emerg identification numbering	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.5 Traveling cables	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.11 Disconnecting means & control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.10 Hoistway construction	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.6 Governor-rope tension devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.12 Controller wiring, fuses, grounding, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.11 Hoistway smoke control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.7 Car Frame & platform	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.13 Governor, overspeed switch, & seal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.12 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.8 Car safeties & guiding memb-incl-roped-hydr elev(*)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.14 Code data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.13 Windows, projections, recesses, & setbacks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.9 (T) Buffers & emerg terminal speed limiting devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.15 (T) Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.14 Hoistway clearances	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.10 (T) Compensating chains, ropes & sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.16 (T) Overhead beam & fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.15 Multiple hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-11 Plunger & cylinder	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.17 (T) Drive machine brake	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.16 Traveling cables & junction boxes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.12 Car Buffer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.18 (T) Traction drive machines	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.17 Door & gate equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.13 Guiding members	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.19 (T) Gears, bearings, & flexible coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.18 Car frame & stiles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5.14 Supply piping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.20 (T) Winding drum mach & slack cable dev	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.19 Guide rails fastening & equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6. ELEVATOR FIRE SERVICE			
2.21 (T) Belt or chain-drive machine	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.20 Governor rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6.1 PH 1 ONLY	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.22 (T) Motor generator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.21 Governor releasing carrier	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6.2 PH 1 & PH 2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.23 (T) Absorption of regenerated power	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.22 Wire rope fastening & hitch plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F.A.I.D. Date <u>11-1-23</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.23 Suspension rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7. ELEVATOR TACTILE IDENTIFICATION			
				3.24 (T) Top counterweight clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(410 ILCS 30/1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

COMMENTS:

OK - meets requirement NG - insert number to identify comment NA - not applicable (T) Traction Cars (*) installed under A17 1b-1989 and later editions

**THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY.
 THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.**

FAIL - RE-INSPECT IN _____ DAYS
 PASS - CONDITION GOOD -
 Approved for Certificate

Elevator Co./Building Representative _____
 Elev Co Lic # IL _____
 Elev Mech Lic # IL _____

Inspector's Signature Anthony J. Pappalardo
 Inspector QEI # C-5684
 Inspector's Lic # IL 05186

2025/26 YR. ANNUAL INSPECTION REPORT
PERIODIC TESTS OF ELECTRIC ELEVATORS
#3 FREIGHT CAR

T 44843

 EIS / Elevator Inspection Service Phone 630.323.6541 • Fax 630.323.7149	Date	12.5.25
	V-T-C	WHEATON
Bldg. Name: <u>WHEATON PROPERTY</u> Address: <u>120 E. LIBERTY</u> Bldg. Phone: Owner / Manager Name	State of IL Reg. I.D.#	1006917
	Date of Last 5 Year Test	11.12.23
	P.O.#	4555219769
	Bldg. I.D.	PASS 3
	Pass / Freight / Service - Make:	KONE
	Speed: 150	Capacity: 3500

Category 1 Test Requirement 8.6.4.19	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			—
Safeties	8.6.4.19.2	X		
Governors	8.6.4.19.3	X		
Slack-Rope Devices on Winding Drum Mach.	8.6.4.19.4			—
Normal & Final Terminal Stopping Devices	8.6.4.19.5	X		
Firefighters' Emergency Operation	8.6.4.19.6	X		
Standby or Emergency Power Operation	8.6.4.19.7	X		
Power Operation of Door System	8.6.4.19.8	X		
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			—
E/E/PES Electrical Protective Devices	8.6.4.19.10	X		

Category 5 Test Requirement 8.6.4.20	ASME Section	Pass	Fail	N/A
Car & Counterweight Safeties	8.6.4.20.1			
Governors	8.6.4.20.2			
Oil Buffers	8.6.4.20.3			
Braking System	8.6.4.20.4			
Emergency and Standby Power Operation	8.6.4.20.5			
Emergency Terminal Stopping & Speed Limiting Devices	8.6.4.20.6			
Power Opening of Doors	8.6.4.20.7			
Leveling Zone & Leveling Speed	8.6.4.20.8			
Inner Landing Zone	8.6.4.20.9			
Emergency Stopping Distance	8.6.4.20.10			

GOVERNOR & SAFETY TEST (Rule 1002.3A)							
Gov. Trip Spd	Prev.	Present	fpm	Gov. Pull Thru			
O.S. Trip Spd	Prev.	Present	fpm	Gov. Pull Out			
Weight Test	No Load X	Full Load	Capacity 3500	Length of Slide-	Left	Right	
Was Load & Speed Test Satisfactory?	Yes	NA	No	Brake at 125%	Yes	No	(No) X
Safety Type	Instant.	Flex Guide X	Other	Was Governor Sealed	Yes X	No	
				Was Governor Tagged	Yes X	No	

OIL BUFFER TEST (Rule 100.2A) Annual	
Load & Speed Test Satisfactory?	Yes NA No
Oil Level & Return Test Satisfactory?	Yes NA No

F.A.I.D. (Fire Alarm Initiating Device) Operation	ASME Section	Pass	Fail	N/A
PASS 11-23	# of Landings			
Total Hours Testing	Machine Room	X		
	Hoistway			
	Pit			

Comments: COMPLETED

Signature of Inspector	<u>Anthony P. Ponzio</u> OEI # <u>05186</u>
Inspector's State of Illinois License #	
Signature of Person Conducting Test & State License #	<u>SHAWN # 02845</u> KONE
Employed by (Company Name)	

2025/26 VR. ANNUAL INSPECTION REPORT

ELEVATOR INSPECTION FORM

I 29895

7-23-25



#3 FREIGHT CAR

EIS / Elevator Inspection Service

Est. 1976



745 McClintock Drive, Suite 235, Burr Ridge, IL 60527 • Phone 630-323-6541 / Fax 630-323-7149

Date _____ Code Edition: ASME A 17.1 _____ A17.3 _____
 V/T/C Wheaton ID # #3 Pass Convey # T006917
 Inspection & Test Routine Periodic Acceptance
 Bldg. Name Wheaton Properties Make Kane Power _____ FL/P/T _____
 Bldg. Rep. _____ Speed 160 fpm Capacity Traction Em Ph _____
 Phone No. _____ TESTING DUE 12/25 2500 Em Light _____

	OK	NG	NA		OK	NG	NA
1. ELEVATOR-INSIDE OF CAR							
1.1 Door reopening device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.24 (T) AC drives from a DC source	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.2 Stop switches	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.25 (T) Traction sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.3 Operating control devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.26 (T) Secondary & deflector sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.4 Sills & car floor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.27 (T) Rope fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.5 Car lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.28 (T) Terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.6 Car emergency signal-lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.29 (T) Car & counterweight safeties	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.7 Car door or gate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.30 Hydraulic power unit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.8 Door closing force	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.31 Relief valves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.9 Power closing of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.32 Control valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.10 Power opening of doors or gates	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.33 Tanks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.11 Car vision panels & glass car doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.34 Flexible hydr hose & fitting assemblies	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.12 Car enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.35 Supply line & shutoff valve	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.13 Emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.36 Hydraulic cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.14 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.37 Pressure switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.15 Signs & operating device symbols	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.38 Robed water hydraulic elevators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.16 Rated load, platform area, & data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.39 Low oil protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.17 Standby power operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.40 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.18 Restricted opening of car or hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.41 Maintenance records	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.19 Car Ride	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2.42 Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. ELEVATOR-MACHINE ROOM				3. ELEVATOR-TOP OF CAR			
2.1 Access to machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.1 Top-of-car stop switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.2 Headroom	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.2 Car top light & outlet	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.3 Lighting & receptacles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.3 Top-of-car operating device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.4 Machine space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.5 Housekeeping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.5 Clearance, refuge space standard railing	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.6 Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.6 Final & emerg terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.7 Fire extinguisher	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.7 Car leveling & anticreep devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.8 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.8 Top emergency exit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.9 Guarding of exposed auxiliary equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.9 Floor & emerg identification numbering	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.10 #ing of elevators, machines, disconnects	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.10 Hoistway construction	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.11 Disconnecting means & control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.11 Hoistway smoke control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.12 Controller wiring, fuses, grounding, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.12 Pipes, wiring & ducts	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.13 Governor, overspeed switch, & seal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.13 Windows, projections, recesses, & setbacks	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.14 Code data plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.14 Hoistway clearances	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.15 (T) Static control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.15 Multiple hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.16 (T) Overhead beam & fastenings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.16 Traveling cables & junction boxes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.17 (T) Drive machine brake	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.17 Door & gate equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.18 (T) Traction drive machines	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.18 Car frame & stiles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.19 (T) Gears, bearings, & flexible coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.19 Guide rails fastening & equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.20 (T) Winding drum mach & slack cable dev	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.20 Governor rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.21 (T) Belt or chain-drive machine	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.21 Governor releasing carrier	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.22 (T) Motor generator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.22 Wire rope fastening & hitch plate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.23 (T) Absorption of regenerated power	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3.23 Suspension rope	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				3.24 (T) Top counterweight clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4. ELEVATOR-OUTSIDE-HOISTWAY			
				4.1 Car platform guard	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.2 Hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.3 Vision panels	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.4 Hoistway door locking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.5 Access to hoistway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.6 Power closing of hoistway doors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.7 Sequence operation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.8 Hoistway enclosure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.9 Elevator Parking devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.10 Emergency doors in blind hoistways	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.11 (T) Separate counterweight hoistway	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.12 Standby power selection switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				4.13 Inspection control	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5. ELEVATOR-PIT			
				5.1 Pit access, lighting, stop switch, & condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.2 Bottom clearance, runby & min. refuge space	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.3 (T) Final & emergency terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.4 Normal terminal stopping devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.5 Traveling cables	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.6 Governor-rope tension devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.7 Car Frame & platform	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.8 Car safeties & guiding memb-incl roped-hydr elev(*)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.9 (T) Buffers & emerg terminal speed limiting devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.10 (T) Compensating chains, ropes & sheaves	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5-11 Plunger & cylinder	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.12 Car Buffer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.13 Guiding members	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				5.14 Supply piping	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				6. ELEVATOR FIRE SERVICE			
				6.1 PH 1 ONLY	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				6.2 PH 1 & PH 2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				F.A.I.D. Date <u>11-1-23</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				7. ELEVATOR TACTILE IDENTIFICATION			
				(410 ILCS 30/1)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

COMMENTS: OK - meets requirement NG - insert number to identify comment NA - not applicable (T) Traction Cars (*) installed under A17.1b-1989 and later editions

THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY. THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.

FAIL - RE-INSPECT IN _____ DAYS
 PASS - CONDITION GOOD -
 Approved for Certificate

Elevator Co./Building Representative _____ Inspector's Signature *[Signature]*
 Elev Co Lic # IL _____ Inspector QEI # C5684
 Elev Mech Lic # IL _____ Inspector's Lic # IL 05186