

CERTIFICATION / INSPECTION REPORT

emailed 10/10/25

SUBSCRIBER		ALARM COMPANY	
Name	Salt Creek Campus 901	DETECTION SYSTEMS & SERVICE, INC.	
Address	901 Elm St	17W725 Butterfield, Suite D	
C-S-Z	Hinsdale, IL	Oakbrook Terrace, IL 60181	
Phone		Phone: (630) 705-9585	

FIRE ALARM CONTROL PANEL											
Manufacturer/model: Gamewell 7100-1D						Number of Zones:					
Does panel indicate normal condition:	Y	<input checked="" type="checkbox"/>	N	<input type="checkbox"/>	Does the silence switch operate:	Y	<input checked="" type="checkbox"/>	N	<input type="checkbox"/>		
Are all indicating lights in working order:	Y	<input checked="" type="checkbox"/>	N	<input type="checkbox"/>	Are the batteries Properly charged:	Y	<input checked="" type="checkbox"/>	N	<input type="checkbox"/>		
Does trouble light operate:	Y	<input checked="" type="checkbox"/>	N	<input type="checkbox"/>	Batteries:	Qty: 2	Volt: 12	AH: 12			

FIRE DETECTION INITIATION AND ANNUNCIATION DEVICES											
Device	Qty	Tested	Cleaned	Pass	Fail	Device	Qty	Tested	Cleaned	Pass	Fail
Remote Annun.	1	1		1		Smoke Det. (Photo)	60	60		60	
Audio/Visual	45	45		45		Smoke Det.(Ion)					
Visuals only	33	33		33		Smoke Det. (Duct)	1	1		1	
Bells						Thermal Det. (ROR)					
Waterflow (Paddle)	4	4		4		Thermal Det. (FT)					
Waterflow (Pressure)						Manual Pull Station	9	9		9	
Valve Tamp. (OS&Y)	6	6		6							
Valve Tamp. (PIV)											
NAC Power Expander	4	4		4							

SPRINKLER SYSTEM SUPERVISORY DEVICES						
Main Drain Test	Static Pressure 70 psi			Residual Pressure (flowing) 65 psi		
Waterflow	Riser #1	Riser #2	Riser #3	Riser #4	Riser #5	Riser #6
	2nd fl	1st fl	Bsmt	Main		
Delay (secs)	40 sec	42 sec	48sec	41 sec		

REMOTE MONITORING			
Monitoring Station Type:	Central		Transmitter Type: Radio
Monitoring Performed by:	Ducom		Connection Date:
Phone / Channel numbers used in transmission:			
Did Fire Alarm panel transmit properly for:	Alarm: yes	Trouble: yes	Alarm Trouble Over Ride: yes

NOTES/COMMENTS

Inspector name: _____ Inspection: Pass: Fail:

DEVIATIONS FROM NFPA72

INSPECTION

Inspection performed by: Manuel Godinez NICET NO 236623 Date: 10-7-2025