

CERTIFICATION / INSPECTION REPORT

Emailed 10/10/25

SUBSCRIBER						ALARM COMPANY						
Name Salt Creek Campus 907						DETECTION SYSTEMS & SERVICE, INC.						
Address 907 Elm St						17W725 Butterfield, Suite D						
C-S-Z Hinsdale, IL						Oakbrook Terrace, IL 60181						
Phone						Phone: (630) 705-9585						
FIRE ALARM CONTROL PANEL												
Manufacturer/model: Notifier NFW2-100												
Number of Zones:												
Does panel indicate normal condition:			Y	☒	N	Does the silence switch operate:			Y	☒	N	
Are all indicating lights in working order:			Y	☒	N	Are the batteries Properly charged:			Y	☒	N	
Does trouble light operate:			Y	☒	N	Batteries:		Qty: 2	Volt: 12	AH: 18		
FIRE DETECTION INITIATION AND ANNUNCIATION DEVICES												
Device	Qty	Tested	Cleaned	Pass	Fail	Device	Qty	Tested	Cleaned	Pass	Fail	
Remote Annun.	1	1		1		Smoke Det. (Photo)	32	32		32		
Audio/Visual	40	40		40		Smoke Det.(Ion)						
Visuals only	23	23		23		Smoke Det. (Duct)	4	4		4		
Bells						Thermal Det. (ROR)						
Waterflow (Paddle)	4	4		4		Thermal Det. (FT)						
Waterflow (Pressure)						Manual Pull Station	8	8		8		
Valve Tamp. (OS&Y)	5	5		5								
Valve Tamp. (PIV)												
NAC Power Expander	3	3		3								
SPRINKLER SYSTEM SUPERVISORY DEVICES												
Main Drain Test	Static Pressure					Residual Pressure (flowing)						
	psi						psi					
Waterflow	Riser #1		Riser #2		Riser #3		Riser #4		Riser #5		Riser #6	
	3rd fl		2nd fl		1st fl		Main					
Delay (secs)	44 sec		45 sec		43 sec		43 sec					
REMOTE MONITORING												
Monitoring Station Type: Central						Transmitter Type: Radio						
Monitoring Performed by: Ducom						Connection Date:						
Phone / Channel numbers used in transmission:												
Did Fire Alarm panel transmit properly for:			Alarm: yes			Trouble: yes			Alarm Trouble Over Ride: yes			
NOTES/COMMENTS												
Inspector name:						Inspection:		Pass:		☒ Fail: ☐		
DEVIATIONS FROM NFPA72												
INSPECTION												
Inspection performed by: Manuel Godinez						NICET NO 236623			Date: 10-7-2025			