

Report of Inspection / Test

Annual NFPA 10



06-24-2026

Property

Shambaugh-369 Roosevelt Rd (4)
369 Roosevelt Rd
Glen Ellyn IL 60137

Conducted by: Evan D.

U.S. Fire & Safety Equipment Co.
0064-AB
2412 Millennium Dr
Elgin IL 60124
7737634422 x201
ppaschall@usfsco.com

Inspection Summary

This is to certify that our representative has inspected the equipment noted below and that he has left the equipment in operating condition. There is available in our file, a complete record of conditions as found and all repairs made and recommended.

FIRE EXTINGUISHER SUMMARY

TYPE	TECHNICIAN	QTY INSPECTED	QTY FAILED	DATE INSPECTED
Abc	Evan D.	4	0	06-24-2026

Report of Inspection / Test

Annual NFPA 10



06-24-2026

Property

Shambaugh-369 Roosevelt Rd (4)
369 Roosevelt Rd
Glen Ellyn IL 60137

Conducted by: Evan D.

U.S. Fire & Safety Equipment Co.
0064-AB
2412 Millennium Dr
Elgin IL 60124
7737634422 x201
ppaschall@usfsco.com

Portable Fire Extinguisher Summary

Type	Tested	Pass	Fail	Not Tested	Total
ABC	4	4	0	0	4

Portable Fire Extinguishers Inspection List - F45 TRAINING

Serial Number	Make	Model	Location	Desc	Type	Size	Year of Mfr.	5 Year	6 Year	12 Year	Status	Notes
	Badger		Front entrance	Fork	ABC	5#	2023	N/A	2041	2035	Pass	
	Badger		Back exit	Fork	ABC	5#	2018	N/A	2036	2030	Pass	

Portable Fire Extinguishers Inspection List - MATTRESS FIRM

Serial Number	Make	Model	Location	Desc	Type	Size	Year of Mfr.	5 Year	6 Year	12 Year	Status	Notes
	Ansul		Front entrance	Fork	ABC	5#	2005	N/A	2031	2037	Pass	
	Ansul		Back exit	Fork	ABC	5#	2012	N/A	2031	2037	Pass	

Report of Inspection / Test

Annual NFPA 10



06-24-2026

Property

Shambaugh-369 Roosevelt Rd (4)
369 Roosevelt Rd
Glen Ellyn IL 60137

Conducted by: Evan D.

U.S. Fire & Safety Equipment Co.
0064-AB
2412 Millennium Dr
Elgin IL 60124
7737634422 x201
ppaschall@usfsco.com

Deficiencies - F45 Training

None

Deficiencies - Mattress firm

None